

Maintena	nce Check List
Installation Completion Date: 11-5-	-1.5
Address: 3720 Venezia	Way
The following items have been prov system owner or system owner's rep	
<ul> <li>frequency of maintenance is a</li> <li>A permanent sticker has been warranty period for the irrigate</li> </ul>	e.  uire maintenance and the recommended attached  attached to the controller indicating the tion system and contact information.  sign plans indicating the actual of the system.
Irrigation system owner/representati	ive Date
state and local laws, ordinances, rule the system and determined that it ha	alled in accordance with all applicable es, regulations or orders. I have tested as been installed according to the ted for the most efficient application of
ASON E STUBBLEFIELD	Irrigation Technician/ Date

## Best of Texas

POBOX 776 HUTTO, TX 78634

(512)228-4833 (512)852-9633 fax

Zone #	Description	Head Type	Run Time(Minutes)
1-2	bed	Spray-bubbl	er 10-12
3-6	turf	sprau	25
7-11	turf	Rotor	45
12	grass	drip	30
	V		
			,
			×
		(	

Month	Average
	Cycles
Jan.	3
Feb.	3
March	4
April	4
May	7
June	9
July	11
Aug.	11
Sept.	9
Oct.	6
Nov.	4
Dec.	3

## **MAINTENANCE ITEMS**

Backflow device – Test Annually (Call Louis Sinclair 563-8762)
Y-strainer – Check annually for debris
Heads – Run system monthly to check for leaks or broken nozzles
Valve covers – Trim grass around cover to expose
Controller – Check seasonally for correct run times
Winter – Run system briefly every 2 weeks if system remains in off position

Quantity	Symbol	Description	Part Number	Pressure	Flow	Radius
Sprinkler		B-0-011-patori	T GIT ITGING	1 1000010	1.011	1100100
2	•	Rain Bird 10F - 1804	10F	30 psi	1.58 gpm	10 ft
19	•	Rain Bird 10H - 1804	10H	30 psi	0.79 gpm	
23	•	Rain Bird 10Q	10Q	30 psi	0.39 gpm	
2	0	Rain Bird 1300A-F	1300AF	30 psi	1.7 gpm	0 ft
1		Rain Bird 5000-MPR-30-F - 5004-PL-FC	MPR-30-F	45 psi	5.78 gpm	30 ft
8	•	Rain Bird 5000-MPR-30-H - 5004-PL-PC	MPR-30-H	45 psi	2.96 gpm	
12		Rain Bird 5000-MPR-30-Q - 5004-PL-PC	MPR-30-Q	45 psi	1.4 gpm	30 ft
22	•	Rain Bird 8H - 1804	8H	30 psi	0.52 gpm	8 ft
14	•	Rain Bird 8Q - 1804	8Q	30 psi	0.26 gpm	
Meters/Pu	umps					
1	M			1		
Backflow	Devices			1		
1	(10)	Febco 715 - 1"	715 - 1"	1		
Control V	alves	4		*:		
13	•	Rain Bird 100-DVF	100-DVF	]		
Y-Straine	rs / Filter	S				
1		Febco 650A-1"	4305	1		
Irrigation	Accesso	ries				
1	M	Nelson 9501-100IN	9501-100IN	1		
1	A	Rain Bird E-4c	E-4c			
1		Rain Bird RSD-BEx	RSD-BEx			
Lateral Li	ne Pipe				6	
1157 ft		Class 200 1"	0	1	11	
Mainline	Pipe	**************************************	l			
306 ft		Class 200 1"	0	1		
Drip Tubi	ng				11	100
118 ft		Rain Bird LD-09-12	LD-09-12	1		


## **3720 VENEZIA VIEW**

Design pressure all zones 65psi.





## **JASON STUBBLEFIELD** 11/5/2015



Water Source #1	
Meter Size	5/8 inch meter
Static Pressure	65 psi
Elevation Change	0 ft

Service Line Information		
Pipe Category	Class 200 PVC	
Pipe Size	Class 200 1"	
Length	5 ft	
Velocity	5 fps	

Recommendations		
Maximum Recommended Flow	13 gpm	
Available Working Pressure	58.39 psi	

