

Maintenance Check List

IVIG	interiaries cricek	List
Installation Completion Date:	: 11-14-15	
Address: 6853 Leor	nard	
The following items have bee system owner or system owner		
frequency of maintenantA permanent sticker has	chedule. nat require maintence is attached as been attached to cirrigation system awn design plans inents of the system	nance and the recommended the controller indicating the and contact information. Indicating the actual
Irrigation system owner/repre	esentative	Date
This irrigation system has been state and local laws, ordinance the system and determined the irrigation plan and is properly water at this time.	es, rules, regulation at it has been insta	ons or orders. I have tested alled according to the
SATE OF TELE	In	rigator/Date

Irrigation Technician/ Date

Best of Texas

POBOX 776 HUTTO, TX 78634 (512)228-4833 (512)852-9633 fax

Zone #	Description	Head Type	Run Time(Minutes)
1	bed	spray-bubb	oler 10-12
2-4	turf	spraus	25
5-12	turf	rotors	45
13	grass	drip	30

Month	Average	
	Cycles	
Jan.	3	
Feb.	3	
March	4	
April	4	
May	7	
June	9	
July	11	
Aug.	11	
Sept.	9	
Oct.	6	
Nov.	4	
Dec.	3	

MAINTENANCE ITEMS

Packflow device – Test Annually (Call Louis Sinclair 563-8762)
Y-strainer – Check annually for debris
Heads – Run system monthly to check for leaks or broken nozzles
Valve covers – Trim grass around cover to expose
Controller – Check seasonally for correct run times

Controller - Check seasonally for correct run times

Winter - Run system briefly every 2 weeks if system remains in off position

Quantity	Symbol	Description	Part Number
Sprinkler	S		
2		Rain Bird 10F - 1804	10F
16	•	Rain Bird 10H - 1804	10H
23	•	Rain Bird 10Q	10Q
2	0	Rain Bird 1300A-F	1300AF
7	•	Rain Bird 5000-MPR-30-H - 5004-PL-PC	MPR-30-H
22		Rain Bird 5000-MPR-30-Q - 5004-PL-PC	MPR-30-Q
7	•	Rain Bird 8H - 1804	8H
9	•	Rain Bird 8Q - 1804	8Q
Meters/Pu	ımps		
1	M		
Backflow	Devices		
1	8	Febco 715 - 1"	715 - 1"
Control V	alves		
14		Rain Bird 100-DVF	100-DVF
Y-Straine	rs / Filter	S	
1	-	Febco 650A-1"	4305
Irrigation	Accesso	ries	
1	M	Nelson 9501-100IN	9501-100IN
1	A	Rain Bird E-4c	E-4c
1		Rain Bird RSD-BEx	RSD-BEx
Lateral Li	ne Pipe		
1319 ft		Class 200 1"	0
Mainline I	Pipe		
249 ft		Class 200 1"	0
Drip Tubir	ng		
182 ft		Rain Bird LD-09-12	LD-09-12

Water Source #1		
Meter Size	5/8 inch meter	
Static Pressure	65 psi	
Elevation Change	0 ft	
Service Line Information		
Pipe Category	Class 200 PVC	
Pipe Size	Class 200 1"	
Length	5 ft	
Velocity	5 fps	
Recommendations		
Maximum Recommended Flow	13 gpm	
Available Working Pressure	58.39 psi	

6853 LEONARD

Design pressure all zones 65psi.





JASON STUBBLEFIELD 11/14/2015



