

Texas Commission on Environmental Quality  
**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping \*purposes:

NAME OF PWS:	City of Leander
PWS ID#:	2460012
MAILING ADDRESS:	PO Box 319 Leander, TX 78646
CONTACT PERSON:	Christi Williams
LOCATION OF SERVICE:	2724 Rain Song Dr.

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY:** ☐ Reduced Pressure Principle ☐ Reduced Pressure Principle-Detector  
☒ Double Check Valve ☐ Double Check-Detector  
☐ Pressure Vacuum Breaker ☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer:	Febco	Size:	1"
Model Number:	850	Located At:	10' NE OF METER
Serial Number:	HE25743		

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? ☒ Yes ☐ No

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1 <sup>st</sup> Check	2 <sup>nd</sup> Check			
Initial Test	Held at <u>2.8</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.7</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ____ psid Did not open <input type="checkbox"/>	Opened at ____ psid Did not open <input type="checkbox"/>	Held at ____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used**					
Test After Repair	Held at ____ psid Closed Tight <input type="checkbox"/>	Held at ____ psid Closed Tight <input type="checkbox"/>	Opened at ____ psid	Opened at ____ psid	Held at ____ psid

Test gauge used:

Make/Model:	Midwest / 845-3	SN:	06111314	Date tested for accuracy:	06/01/2017
Remarks:					
None					

**The above is certified to be true at the time of testing.**

Firm Name:	L Sinclair Services Inc.	Certified Tester Name (Print/Type):	Lewis R. Sinclair
Firm Address:	Cedar Park, TX 78613	Certified Tester Name (Signature):	
Firm Phone #:	512-563-8762	Cert. Tester No.:	BP0002815
		Date of Test:	07/19/17

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS

\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS