



ROUND ROCK TEXAS

# NEW INSTALLATION

## CROSS CONNECTION SECTION TEST AND MAINTENANCE REPORT

Account # \_\_\_\_\_  
(Office Use)

Bldg. Permit # \_\_\_\_\_

Testing Firm Name: L SINCLAIR SERVICES INC

Address: MACHADO ROAD

City, State, Zip: CEDAR PARK TX 78613

Email: LSS@AUSTIN.RR.COM

Telephone: 512-563-8162 Certified Fire Line Contractor  Fire Line Test

Property Owner/Business Name: TAYLOR MORRISON Commercial  Residential

Property Address: 2142 SURANO AVE City: ROUND ROCK State: TX Zip: 78665

Mailing Address: 11200 LAKEVIEW BLVD City: AUSTIN State: TX Zip: 78717

Owner/Contact: TAYLOR MORRISON Phone: 512-328-8866

Email: NA

Device Serial #: HE28975 Size: 1" Manufacturer: FERD Model: 85C

Device Location: 8' NE OF METER Reason Installed: LANDSCAPE IRRIGATION  
Type of Cross-Connections

	REDUCED PRESSURE PRINCIPLE ASSEMBLY		PRESSURE VACUUM BREAKER		
	DOUBLE-CHECK ASSEMBLY		Relief Valve	Air Relief	Check Valve
	1st Check	2nd Check			
Initial Test	DC Closed tight <input checked="" type="checkbox"/> Leaked <u>A</u> <input checked="" type="checkbox"/> PSI <u>2.1</u> RPZ _____ PSID	Closed tight <input checked="" type="checkbox"/> Leaked <u>2.5</u> <input checked="" type="checkbox"/> PSI _____	Opened at _____ PSID	Opened at _____ PSID  Did not open <input type="checkbox"/>	Closed at _____ PSID  Did not close <input type="checkbox"/>
Materials & Repairs					
Test After Repairs	DC Closed tight <input type="checkbox"/> PSI _____ RPZ _____ PSID	Closed tight <input type="checkbox"/> PSI _____	Opened at _____ PSID	Opened at _____ PSID	Closed at _____ PSID

Has this device been installed according to manufacturer's specs or code? Yes  No

Test Results: Pass  Fail

The above is certified to be true.

Gauge Serial #: 0211314 Calibration Date: 06/01/17

City of Round Rock - Building Inspection Department

Tester Printed Name: LEWIS R SINCLAIR

301 W. Bagdad #100, Round Rock, TX 78664

Certified Tester # BPO002515 Test Date: 07/19/17

Phone: 512-218-5550

Tester Signature: Lewis R Sinclair

WARNING: City of Round Rock must have current copies of tester's BPAT license and gauge calibration certification or report will not be accepted.

**FORM MUST REMAIN ON-SITE FOR INSPECTION DEPARTMENT**