



ROUND ROCK TEXAS

NEW INSTALLATION

CROSS CONNECTION SECTION TEST AND MAINTENANCE REPORT

Bldg. Permit # _____

Account # _____
(Office Use)

Testing Firm Name: L SINCLAIR SERVICES INC

Address: MACHADO ROAD

City, State, Zip: CEDAR PARK TX 78613

Email: LSS@AUSTIN.RR.COM

Telephone: 512-563-8162 Certified Fire Line Contractor Fire Line Test

Property Owner/Business Name: TAYLOR MORRISON Commercial Residential

Property Address: 7100 ENZA COURT City: ROUND ROCK State: TX Zip: 78665

Mailing Address: 11700 LAKEVIEW BLVD City: AUSTIN State: TX Zip: 78717

Owner/Contact: TAYLOR MORRISON Phone: 512-328-9866

Email: NA

Device Serial #: HE30572 Size: 1" Manufacturer: FEBLO Model: 950

Device Location: 6 W OF METER Reason Installed: IRRIGATION
Type of Cross-Connections

	REDUCED PRESSURE PRINCIPLE ASSEMBLY		PRESSURE VACUUM BREAKER		
	DOUBLE-CHECK ASSEMBLY		Relief Valve	Air Relief	Check Valve
	1st Check	2nd Check			
Initial Test	DC Closed tight <input checked="" type="checkbox"/> Leaked <input checked="" type="checkbox"/> <u>2.8</u> PSI RPZ _____ PSI	Closed tight <input checked="" type="checkbox"/> Leaked <input checked="" type="checkbox"/> <u>2.8</u> PSI	Opened at _____ PSI	Opened at _____ PSI Did not open <input type="checkbox"/>	Closed at _____ PSI Did not close <input type="checkbox"/>
Materials & Repairs					
Test After Repairs	DC Closed tight <input type="checkbox"/> PSI _____ RPZ _____ PSI	Closed tight <input type="checkbox"/> PSI _____	Opened at _____ PSI	Opened at _____ PSI	Closed at _____ PSI

Has this device been installed according to manufacturer's specs or code? Yes No
Test Results: Pass Fail

The above is certified to be true.
Gauge Serial #: CG11314 Calibration Date: 04/01/17
Tester Printed Name: LEWIS R. SINCLAIR
Certified Tester # BPC002B Test Date: 11/15/17
Tester Signature: Lewis R. Sinclair

City of Round Rock - Building Inspection Department
301 W. Bagdad #100, Round Rock, TX 78664
Phone: 512-218-5550

WARNING: City of Round Rock must have current copies of tester's BPAT license and gauge calibration certification or report will not be accepted.
FORM MUST REMAIN ON-SITE FOR INSPECTION DEPARTMENT