

Texas Commission on Environmental Quality
BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

4121

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	City of Leander
PWS ID#:	2460012
MAILING ADDRESS:	PO Box 319 Leander, TX 78646
CONTACT PERSON:	Christi Williams
LOCATION OF SERVICE:	4220 Vespa Cove

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY: Reduced Pressure Principle Reduced Pressure Principle-Detector
 Double Check Valve Double Check-Detector
 Pressure Vacuum Breaker Spill-Resistant Pressure Vacuum Breaker

Manufacturer:	Febco	Size:	1"
Model Number:	850	Located At:	T.E.S.E. OF METER
Serial Number:	HE3117		

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes No

	Reduced Pressure Principle Assembly		Relief Valve	Pressure Vacuum Breaker	
	Double Check Valve Assembly			Air Inlet	Check Valve
	1 st Check	2 nd Check			
Initial Test	Held at <u>2.2</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.2</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Held at ___ psid Leaked <input type="checkbox"/>
Repairs and Materials Used**					
Test After Repair	Held at ___ psid Closed Tight <input type="checkbox"/>	Held at ___ psid Closed Tight <input type="checkbox"/>	Opened at ___ psid	Opened at ___ psid	Held at ___ psid

Test gauge used:

Make/Model:	Midwest / 845-3	SN:	06111314	Date tested for accuracy:	06/01/2017
Remarks:	Residential Irrigation				

The above is certified to be true at the time of testing.

Firm Name:	L Sinclair Services Inc.	Certified Tester Name (Print/Type):	Lewis R. Sinclair
Firm Address:	Cedar Park, TX 78613	Certified Tester Name (Signature):	<i>[Signature]</i>
Firm Phone #:	512-563-8762	Cert. Tester No.:	BP0002815
		Date of Test:	12/04/17

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS