



ROUND ROCK TEXAS

NEW INSTALLATION

CROSS CONNECTION SECTION TEST AND MAINTENANCE REPORT

Account # _____
(Office Use)

Bldg. Permit # _____

Testing Firm Name: L SINCLAIR SERVICES INC

Address: MACHADO ROAD

City, State, Zip: CEDAR PARK, TX 78613

Email: LSS@AUSTIN.RR.COM

Telephone: 512-563-8762 Certified Fire Line Contractor Fire Line Test

Property Owner/Business Name: TAYLOR MORRISON Commercial Residential

Property Address: 5101 SAVID DR. City: ROUND ROCK State: TX Zip: 78665

Mailing Address: 11700 LAKEVIEW BLVD City: AUSTIN State: TX Zip: 78717

Owner/Contact: TAYLOR MORRISON Phone: 512-328-9866

Email: NA

Device Serial #: HE50952 Size: 1" Manufacturer: FEBCO Model: 850

Device Location: 2' ESE OF METER Reason Installed: LANDSCAPE IRRIGATION
Type of Cross-Connections

	REDUCED PRESSURE PRINCIPLE ASSEMBLY		PRESSURE VACUUM BREAKER		
	DOUBLE-CHECK ASSEMBLY		Relief Valve	Air Relief	Check Valve
	1st Check	2nd Check			
Initial Test	DC Closed tight <input checked="" type="checkbox"/> Leaked <input checked="" type="checkbox"/> <u>2.2</u> PSI RPZ _____ PSID _____	Closed tight <input checked="" type="checkbox"/> Leaked <input checked="" type="checkbox"/> <u>2.9</u> PSI	Opened at _____ PSID	Opened at _____ PSID Did not open <input type="checkbox"/>	Closed at _____ PSID Did not close <input type="checkbox"/>
Materials & Repairs					
Test After Repairs	DC Closed tight <input type="checkbox"/> PSI _____ RPZ _____ PSID _____	Closed tight <input type="checkbox"/> PSI _____	Opened at _____ PSID	Opened at _____ PSID	Closed at _____ PSID

Has this device been installed according to manufacturer's specs or code? Yes No

Test Results: Pass Fail

The above is certified to be true.
Gauge Serial #: 0611314 Calibration Date: 02/01/17
Tester Printed Name: LEWIS R. SINCLAIR
Certified Tester # BPO002815 Test Date: 02/05/18
Tester Signature: Lewis R. Sinclair

City of Round Rock - Building Inspection Department
301 W. Bagdad #100, Round Rock, TX 78684
Phone: 512-218-5650

WARNING: City of Round Rock must have current copies of tester's BPAT license and gauge calibration certification or report will not be accepted.
FORM MUST REMAIN ON-SITE FOR INSPECTION DEPARTMENT