

# Backflow Prevention Assembly Test and Maintenance Report

NAME OF PWS: HAYS COUNTY WCID #2  
 PWS I.D. #: 1030148  
 MAILING ADDRESS: ~~420141 PARKER LN. BUILDING B. SLITTER RD. AUSTIN, TX 78727~~  
 CONTACT PERSON: ~~RS~~ HIGHLAND HOMES TRENDMAKER  
 LOCATION OF SERVICE: 12908 MESA VERDE DR

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer FEBCO Size 1"  
 Model Number 850 Located At 9' SSW OF METER  
 Serial Number HE74790

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? YES

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check		Opened at ___ psid	Held at ___ psid
Initial Test	Held at <u>0</u> psid Closed Tight <input type="checkbox"/> Leaked <input checked="" type="checkbox"/>	Held at ___ psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Did not open <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>
Repairs and Materials Used	<u>CLEAN FLUSH</u>				
Test After Repair	Held at <u>2.5</u> psid Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.5</u> psid Closed Tight <input checked="" type="checkbox"/>	Opened at ___ psid	Opened at ___ psid	Held at ___ psid

Test gauge used: Make/Model MIDWEST/245.3 SN: 06111314 Calibration Date: 05/14/18

Remarks:

The above is certified to be true at the time of testing.  
 Firm Name LSINCLAIR SERVICES INC. Certified Tester Amis R. Sinclair  
 Firm Address CEDAR PARK, TX 78613 Cert. Tester No. B90002815 Date 12/03/19  
 Firm Phone # 512-563-8762

\*TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS.