

This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.

# **COMPLETION ITEMS PROVIDED**

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.

## **Recommended Maintenance**

- Backflow Test Annually (contact Lewis Sinclair 512-563-8762)
- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads
- Valve Covers Trim grass to keep exposed
- Controller Seasonal update programming
- Winter Run system briefly every 2 weeks if system turned off

## **Recommended Monthly Cycles**

(Water Days)

	January	3
_	F - I	2

- February
- March
- April
- May
- June 9
- 3 direction 3
- July 11August 11
- August 1September 9
- October 6
- November 4
- December 3





## **Recommended Run Times** (minutes)

•	Spray – Shrub	12
•	Spray – Lawn	25

Rotor – Lawn 45

## **Legend**

© Backflow

Control Valve


□ Spray - Shrub

Spray - Lawn

**▼** Rotor - Lawn

Drip Tubing

- • Main Line



# 4300 ORANGE BLOSSOM PASS

REVISIONS:
COMPLETION:
12/16/18

DAITE:
2018 - 11 / 29
JOB NUMBER:
78641-ORA-4300
DRAWN BY:
SINCLAIR
CHECKED BY:
STUBBLEFIELD
SCALE:
1" = 20'
SHEET:

### PROJECT:

4300 ORANGE BLOSSOM PASS LEANDER, TX 78641

LOT 26, BLOCK A



### COMPANY:

BEST OF TEXAS LANDSCAPES LIBERTY HILL, TEXAS 78642

(512) 260-1430

www.bestoftexaslandscapes.com