for the most efficient application of water at this time.

This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or

orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted

COMPLETION ITEMS PROVIDED

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.

Recommended Maintenance

- Backflow Test Annually (contact Lewis Sinclair 512-563-8762)
- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads
- Valve Covers Trim grass to keep exposed
- Controller Seasonal update programming

3

Winter – Run system briefly every 2 weeks if system turned off

Recommended Monthly Cycles

(Water Days)

January	

February

March 4

• April

Mav

June9

July 11

August 11

September 9

October 6

November 4

December 3

JASON STUBBLEFIELD
12003
SED IRRIGO



Recommended Run Times (minutes)

Spray – Shrub 12
 Spray – Lawn 25
 Rotor – Lawn 45

Legend

© Backflow

Control Valve


☐ Spray - Shrub

Spray - Lawn

▼ Rotor - Lawn

Drip Tubing

- - • Main Line



1544 FERRARI DRIVE

REVISIONS: COMPLETION: 01/18/19 DATE: 2018 - 12 / 16 JOB NUMBER: 78641-FER-1544 DRAWM BY: SINCLAIR CHECKED BY: STUBBLEFIELD SCALE: 1" = 20' SHEET:

PROJEC 1544 FERRARI DRIVE

1544 FERRARI DRIVE LEANDER, TX 78641

LOT 14, BLOCK Z TRAVISSO



COMPANY:

BEST OF TEXAS LANDSCAPES LIBERTY HILL, TEXAS 78642

(512) 260-1430

www.bestoftexaslandscapes.com