



Backflow Prevention Assembly Test and Maintenance Report

Name of PWS REUNION RANCH PWS I.D. # 1050175
PWS Mailing Address 14050 SUMMIT DRIVE SUITE 103 AUSTIN, TX 78728
PWS Contact Person SCOTT MANUEL, MISSY ROBERTS, PHIL HENDERSON
Address of Service 879 JACKSON DR.

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Type of Assembly

- ☐ Reduced Pressure Principle (RPBA) ☐ Reduced Pressure Principle-Detector (RPBA-D)
☒ Double Check Valve (DCVA) ☐ Double Check-Detector (DCVA-D)
☐ Pressure Vacuum Breaker (PVB) ☐ Spill-Resistant Pressure Vacuum Breaker (SVB)

Manufacturer FEBLO Size 1

Model Number 850 BPA Location 9' ESE OF METER

Serial Number HE79833 BPA Serves LANDSCAPE IRRIGATION

Reason for Test: ☒ New ☐ Existing ☐ Replacement Old Model/Serial Number N/A

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? ☒ Yes ☐ No

Is the assembly installed on a non-potable water supply (auxiliary)? ☐ Yes ☒ No

	Reduced Pressure Principle (RPBA)			PVB & SVB	
	Double Check Valve (DCVA)		Relief Valve	Air Inlet	Check Valve
	1 st Check	2 nd Check***			
Initial Test	Held at <u>25</u> psid	Held at <u>35</u> psid	Opened at ____ psid	Opened at ____ psid	Held at ____ psid
Date: <u>12/11/18</u>	<input checked="" type="checkbox"/> Closed Tight	<input checked="" type="checkbox"/> Closed Tight	<input type="checkbox"/> Did not open	<input type="checkbox"/> Did not open	<input type="checkbox"/> Leaked
Time: <u>10:35 AM</u>	<input type="checkbox"/> Leaked	<input type="checkbox"/> Leaked		Did it fully open? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Repairs and Materials Used**					
Test After Repair	Held at ____ psid	Held at ____ psid	Opened at ____ psid	Opened at ____ psid	Held at ____ psid
Date: _____	<input type="checkbox"/> Closed Tight	<input type="checkbox"/> Closed Tight			
Time: _____					

*** 2nd Check: Numeric reading required for DCVA only

Differential Pressure Gauge Used ☒ Potable ☐ Non-Potable

Make/Model MIDWEST/845-3 Serial Number 06111314 Date tested for accuracy 05/14/18

Remarks NONE

Company Name Inframark Licensed Tester Name (print/type) LEWIS R. SIMLAIR
Company Address 14050 Summit Dr., Austin, TX 78728 Licensed Tester Name (signature) Lewis R. Simlair
Company Phone 512-246-0498 BPAT License # BP0002915 Expiration Date 02/12/2020

The above is certified to be true at the time of testing.

* Test records must be kept for at least three years [30 TAC §290.46(B)]

** Use only manufacturer's replacement parts

Test Result

☒ Pass ☐ Fail