0 10 20 1" = 20'

**Recommended Maintenance** 

- Backflow Test Annually (contact Lewis Sinclair 512-563-8762)
- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads
- Valve Covers Trim grass to keep exposed
- Controller Seasonal update programming
- Winter Run system briefly every 2 weeks if system turned off

# **COMPLETION ITEMS PROVIDED**

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.

## **Recommended Monthly Cycles**

(Water Days)

- January 3
- February 3
- March
- April
- May
   7
- ....
- June 9
- July 11
- August 11
- September 9
- October 6
- November 4
- December 3

### **Recommended Run Times** (minutes)

| <ul><li>S</li></ul> | pray | -S | hru | b |
|---------------------|------|----|-----|---|
|---------------------|------|----|-----|---|

12 25

Spray – Lawn

45

Rotor – Lawn

# **Legend**

© Backflow

Control Valve


☐ Spray - Shrub

Spray - Lawn

▼ Rotor - Lawn

Drip Tubing

- - Main Line



5095 CASSIA WAY





This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.



# PROJECT: 5095 CASSIA WAY ROUND ROCK, TX 78665 LOT 21 BLK H VIZCAYA



BEST OF TEXAS LANDSCAPES LIBERTY HILL, TEXAS 78642 (512) 260-1430

www.bestoftexaslandscapes.com