



# Backflow Prevention Assembly Test and Maintenance Report

Name of PWS HAYS COUNTY WCID #2 PWS I.D. # 1050148

PWS Mailing Address 14050 SUMMIT DRIVE SUITE 103 AUSTIN, TX 78728

PWS Contact Person SCOTT MANUEL, MISSY ROBERTS, PHIL HENDERSON

Address of Service 172 GALLATIN COURT

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

### Type of Assembly

- Reduced Pressure Principle (RPBA)
- Double Check Valve (DCVA)
- Pressure Vacuum Breaker (PVB)
- Reduced Pressure Principle-Detector (RPBA-D)
- Double Check-Detector (DCVA-D)
- Spill-Resistant Pressure Vacuum Breaker (SVB)

Manufacturer FEBLO Size 1"

Model Number 850 BPA Location 10' N OF METER

Serial Number HE 92778 BPA Serves LANDSCAPE IRRIGATION

Reason for Test:  New  Existing  Replacement Old Model/Serial Number N/A

Is the assembly installed in accordance with manufacturer recommendations and/or local codes?  Yes  No

Is the assembly installed on a non-potable water supply (auxiliary)?  Yes  No

	Reduced Pressure Principle (RPBA)			PVB & SVB	
	Double Check Valve (DCVA)		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check***			
<b>Initial Test</b>	Held at <u>2.0</u> psid	Held at <u>2.0</u> psid	Opened at _____ psid	Opened at _____ psid	Held at _____ psid
Date: <u>04/13/18</u>	<input checked="" type="checkbox"/> Closed Tight	<input checked="" type="checkbox"/> Closed Tight	<input type="checkbox"/> Did not open	<input type="checkbox"/> Did not open	<input type="checkbox"/> Leaked
Time: <u>02:00 PM</u>	<input type="checkbox"/> Leaked	<input type="checkbox"/> Leaked		Did it fully open? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Repairs and Materials Used**	_____				
<b>Test After Repair</b>	Held at _____ psid	Held at _____ psid	Opened at _____ psid	Opened at _____ psid	Held at _____ psid
Date: _____	<input type="checkbox"/> Closed Tight	<input type="checkbox"/> Closed Tight			
Time: _____					

\*\*\* 2nd Check: Numeric reading required for DCVA only

Differential Pressure Gauge Used  Potable  Non-Potable

Make/Model MIDWEST/945-3 Serial Number 06111314 Date tested for accuracy 05/14/18

Remarks NONE

Company Name Inframark Licensed Tester Name (print/type) LEWIS R. SINCLAIR  
 Company Address 14050 Summit Dr., Austin, TX 78728 Licensed Tester Name (signature) [Signature]  
 Company Phone 512-246-0498 BPAT License # 890002815 Expiration Date 02/12/2020

The above is certified to be true at the time of testing.  
 \* Test records must be kept for at least three years [30 TAC §290.46(B)]  
 \*\* Use only manufacturer's replacement parts

### Test Result

Pass  Fail