

Backflow Prevention Assembly Test Details

**Test and Maintenance Report**

Water System ID# 2270001

Special Services Division
3907 South Industrial DR
Austin, TX 78744-1070

Phone: (512) 972-1060
FAX: (512) 972-1260



*** Test records must be kept by the customer for at least three years ***

Backflow Assembly Information

Serial Number:	HE94298	Manufacturer:	FEBCO
Model:	850	Size:	1
Service Address:	1506 WETHERSFIELD RD 78703		
Assembly location on the property:	8' NORTH-NORTHWEST OF METER.		
Reason the assembly is installed:	IRRIGATION W/ CITY POTABLE WATER		
Is this assembly installed to code requirements?	Yes		

Customer Information

Property Owner / Agent:	NWS CONSTRUCTION
Mailing Address:	3808 MANORWOOD ROAD
City / State / Zip:	AUSTIN, TX 78733
Phone:	(512) 919-6155

Backflow Test

Initial Test	DCVA	
	Check Valve #1	Check Valve #2
	2.4 PSID	2.8 PSID

Repairs**Test After Repairs**

Test Date:	Jul 8, 2019
Backflow Test Status:	Passed

Tester Information

The backflow technician listed below has previously certified that the information on this report was true and correct on the date of this test.

Backflow Technician:	SINCLAIR, LEWIS R
License:	BP0002815
Gauge Serial Number:	06111314