



Irrigation, Water and Wastewater Utility Cross Connection Section Test and Maintenance Report

930AM

*New Installation Date: 072619 Water Meter # NA Permit # _____

**Annual Test Date: _____ **Semi-Annual Test Date: _____

Address: 209 COOPERS HILL ROAD Residential Commercial

Owner/Business Name: ASHBY SIGNATURE HOMES Phone Number: 512-943-9236

Model Number: RP4A Size: 1" Device Location: 10' END OF METERS Serial Number: 901035

Manufacturer: APOLLO Reason device is installed: IRRIGATION^W/ POTABLE WATER

RP DC _____ PVB _____ SVB _____ DCDA _____ RPDA _____ High Health: YES NO:

	REDUCED PRESSURE PRINCIPLE ASSEMBLY		PRESSURE VACUUM BREAKER		
	DOUBLECHECK ASSEMBLY		Relief valve	Air relief	Check valve
	First check	Second check			
INITIAL TEST	closed tight <input type="checkbox"/> leaked <input checked="" type="checkbox"/> p.s.i. <u>8.0</u> RPZ <u>8.0</u> p.s.i.d.	closed tight <input type="checkbox"/> leaked <input type="checkbox"/> p.s.i. _____	opened at <u>8.0</u> p.s.i.d.	opened at _____ p.s.i.d. Did not open <input type="checkbox"/>	closed at _____ p.s.i.d. Did not close <input type="checkbox"/>
BACKFLOW STATUS (CIRCLE)	PASS	FAIL			
MATERIALS AND REPAIRS	<u>CLEAN / FLUSH</u>				
TEST AFTER REPAIRS	closed tight <input checked="" type="checkbox"/> p.s.i. _____ RPZ <u>8.0</u> p.s.i.d.	closed tight <input checked="" type="checkbox"/> p.s.i. _____	opened at <u>4.0</u> p.s.i.d.	opened at _____ p.s.i.d.	closed at _____ p.s.i.d.

I certify the above information to be true and correct to the best of my knowledge.

Property owner/occupant: ASHBY SIGNATURE HOMES owner/Contact: ASHBY SIGNATURE HOMES

Certified Tester: (printed and signed) LEWIS R. SINGLAIR

Mailing address: 1307 MACHADO ROAD City: CEDAR PARK State: TX Zip: 78613

Tester Certif. number: BP0002415 Gauge Serial: 0611314

Tester's phone number: 512-563-8762 Manufacturer MIDWEST Model 845-3

Please forward this completed report to

*** FOR ALL NEW INSTALLATIONS, COMPLETED ORIGINAL TEST FORM MUST BE PLACED IN THE VALVE BOX AND MUST SCHEDULE INSPECTION ONLINE AT MYPERMITNOW.ORG FOR REQUIRED INSPECTION. NEW INSTALLATIONS THAT ARE PART OF NEW CONSTRUCTION FROM THE GROUND UP, ORIGINAL REPORT MUST BE SUBMITTED TOGETHER WITH JOB PACKET AND IS INSPECTED DURING THE BUILDING FINAL INSPECTION.** Questions, please call our office at (512) 930-2550 - **Billing** questions, please call Customer Service at (512)930-3640.

****ANNUAL /SEMI-ANNUAL TEST:** City of Georgetown Customer Care Center, 300-1 Industrial Ave, P O Box 1430, Georgetown, Texas 78627.

E-mail: customercare@georgetown.org

Failure to return this form within 10 business days of inspection may result in disconnection of water service.

****TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS****

*****USE ONLY MANUFACTURER'S REPLACEMENT PARTS*****