Texas Commission on Environmental Quality BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes: NAME OF PWS: City of Pflugerville PWS ID#: **PWS MAILING ADDRESS:** PO Box 589 / 78691, Pflugerville, TX 78660 PWS CONTACT PERSON: Building Department – (512) 990-6300 5109 Anaheim Ave. ADDRESS OF SERVICE: The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters. TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA): Reduced Pressure Principle (RPBA) Reduced Pressure Principle-Detector (RPBA-D) Double Check Valve (DCVA) Double Check-Detector (DCVA-D) \boxtimes Pressure Vacuum Breaker (PVB) Spill-Resistant Pressure Vacuum Breaker (SVB) П П Febco Manufacturer: Size: Model Number: 850 **BPA Location:** 8 WISKI OF MER Serial Number: HE 93200 **BPA Serves:** Residential Landscape Irrigation Reason for test: New 🛛 Existing Replacement Old Model/Serial # Is the assembly installed in accordance with manufacturer recommendations and/or local codes? ⊠ Yes □ No Is the assembly installed on a non-potable water supply (auxiliary)? ☐ Yes ☑ No **TEST RESULT** Reduced Pressure Principle Assembly (RPBA) PVB & SVB PASS 💢 **DCVA** Relief Valve Air Inlet Check Valve 2nd Check*** FAIL 1st Check Held at Z. spsid Held at Z. sid Opened at **Initial Test** Opened at psid Held at psid Closed Tight 🔀 Date:062819 Closed Tight Did not open psid Leaked \Box Time: 1750 PH Did not open Leaked Leaked Did it fully open (Yes □ /No □) Repairs and Materials Used** Test After Repair Held at psid Held at psid Opened at psid Opened at Held at psid Date: psid Closed Tight | Closed Tight | Time: *** 2nd check: numeric reading required for DCVA only Differential pressure gauge used: Potable: Non-Potable: Make/Model: Midwest / 845-3 06111314 SN: Date tested for accuracy: 04/29/19 Remarks: None Company Name: Licensed Tester Name L Sinclair Services Inc. Lewis R. Sinclair (Print/Type): Company Address: Cedar Park, TX 78613 Licensed Tester Name (Signature): Company Phone #: BPAT License # 512-563-8762 BP0002815 License Expiration 02/12/2020 Date:

The above is certified to be true at the time of testing.

^{*} TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

^{**} USE ONLY MANUFACTURER'S REPLACEMENT PARTS