



# CITY OF LAGO VISTA

## DEVELOPMENT SERVICES

5803 THUNDERBIRD SUITE 103  
PO BOX 4727 LAGO VISTA, TX. 78645

Office: 512-267-5259

Fax: 512-267-5265

### BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

New Installation       Annual Test

NAME OF PWS: CITY OF LAGO VISTA  
PWS I.D.: # 2270092  
MAILING ADDRESS: P.O. BOX 4727, LAGO VISTA, TX 78645  
CITY CONTACT PERSON: DEVELOPMENT SERVICES

PROPERTY OWNER'S NAME: HIGHLAND HOMES  
LOCATION OF SERVICE: 7507 KNOTTED SARGE COURT

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

#### TYPE OF ASSEMBLY

Reduced Pressure Principle     Double Check Valve       Reduced Pressure Principle-Detector  
 Double Check-Detector       Pressure Vacuum Breaker       Spill-Resistant Pressure Vacuum Breaker

Manufacturer FERCO      Size 1"  
Model Number 850      Located At 7' SE OF METER  
Serial Number 14F45757

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? YES

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly			Air Inlet	Check Valve
	1st Check	2nd Check	Relief Valve		
Initial Test <u>330P</u>	Held at <u>2.4</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.7</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test gauge used: Make/Model MIDWEST/845-3      SN: 06111314      Calibration Date: 04 21 20

Remarks: NONE  
The above is certified to be true at the time of testing.

Firm Name: L SINCLAIR SERVICES      Certified Tester: [Signature]  
Firm Phone #: 512-563-8162      Cert. Tester No.: 390007819      Date: 01 05 21  
Firm Address: CEDAR PARK, TX 78613