



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: **2460022**

MAILING ADDRESS\_\_ 1008 Moose Rd. Hutto, TX 78634\_\_\_\_\_

CONTACT PERSON \_\_Taylor Morrison \_\_\_\_\_

LOCATION OF SERVICE\_ 1008 Moose Rd. Hutto, TX 78634\_\_\_\_\_

INSPECTION DATE \_\_9/15/2021 1:20 PM\_\_\_\_\_

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure ZONE**
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Febco\_\_\_\_\_

Model # 850\_\_\_\_\_ Serial # HF75796\_\_\_\_\_

Location of device Right front yard near meter\_\_\_\_\_

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes\_\_\_\_\_

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker						
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve				
	1st Check	2nd Check		Opened at	psid	Held at	psid			
Initial Test	Held at 2.1 psid	Held at 2.2 psid	Opened at	psid	Did not Open	□	Leaked	□		
	Closed Tight X Leaked □	Closed Tight X Leaked □	Did not open	□						
Repairs and Materials Used										
Test After Repair	Held at Closed Tight	psid □	Held at Closed Tight	psid □	Opened at	psid	Opened at	psid	Held At	psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845\_\_\_\_\_ SN: 10150482\_\_\_\_\_ Calibration Date:10/9/2020\_\_\_\_\_

Firm Name Safewater Backflow\_\_\_\_\_ Certified Tester Brad Weyant\_\_\_\_\_

Firm Address PO Box 4002 Austin, TX 78765\_\_\_\_\_ Cert. Tester No.BP0016935\_\_\_\_\_

Firm Phone # 512-605-9790

**- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS**