



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: **2460022**

MAILING ADDRESS__ 1006 Sandra Ann Way Hutto, TX 78634_____

CONTACT PERSON __ Taylor Morrison _____

LOCATION OF SERVICE_ 1006 Sandra Ann Way Hutto, TX 78634_____

INSPECTION DATE __ 11/1/2021 12:15PM _____

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- | | |
|--|--|
| <input type="checkbox"/> Reduced Pressure ZONE | <input type="checkbox"/> Reduced Pressure Principle-Detector |
| <input checked="" type="checkbox"/> Double Check Valve | <input type="checkbox"/> Double Check-Detector |
| <input type="checkbox"/> Pressure Vacuum Breaker | <input type="checkbox"/> Spill-Resistant Pressure Vacuum Breaker |

Manufacturer: Febco_____

Model # 850_____ Serial # HF56201_____

Location of device Right front yard near meter _____

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes_____

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker				
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve		
	1st Check	2nd Check		Opened at	psid	Held at	psid	
Initial Test	Held at 2.2 psid	Held at 1.9 psid	Opened at	psid	Did not Open	<input type="checkbox"/>	Leaked	<input type="checkbox"/>
	Closed Tight X Leaked <input type="checkbox"/>	Closed Tight X Leaked <input type="checkbox"/>	Did not open	<input type="checkbox"/>				
Repairs and Materials Used								
Test After Repair	Held at Closed Tight <input type="checkbox"/>	psid Closed Tight <input type="checkbox"/>	Held at Closed Tight <input type="checkbox"/>	psid Closed Tight <input type="checkbox"/>	Opened at	psid	Opened at	psid
			Opened at	psid	Opened at	psid	Held At	psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 10150482 Calibration Date:10/7/2021

Firm Name Safewater Backflow Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765 Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS