

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	Travis County MUD 5
PWS ID#:	44207201
PWS MAILING ADDRESS:	2601 Forest Creek Drive, Round Rock, Texas 78665
PWS CONTACT PERSON:	Backflow Department
ADDRESS OF SERVICE:	626 Rocky Sport Drive, Austin, Tx 78737

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

<input type="checkbox"/>	Reduced Pressure Principle (RPBA)	<input type="checkbox"/>	Reduced Pressure Principle-Detector (RPBA-D) Type II	<input type="checkbox"/>
<input checked="" type="checkbox"/>	Double Check Valve (DCVA)	<input type="checkbox"/>	Double Check-Detector (DCVA-D) Type II	<input type="checkbox"/>
<input type="checkbox"/>	Pressure Vacuum Breaker (PVB)	<input type="checkbox"/>	Spill-Resistant Pressure Vacuum Breaker (SVB)	

Manufacturer:	Main: Febco	Bypass:	Size: 1"	Main:	Bypass:
Model Number:	Main: 850	Bypass:	BPA Location:	Front Left at Meter	
Serial Number:	Main: HF76369	Bypass:	BPA Serves:	Irrigation	

Reason for test:	New <input checked="" type="checkbox"/>	Existing <input type="checkbox"/>	Replacement <input type="checkbox"/>	Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?				<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is the assembly installed on a non-potable water supply (auxiliary)?				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

TEST RESULT	Reduced Pressure Principle Assembly (RPBA)			Type II Assembly	PVB & SVB	
	DCVA		Relief Valve	Bypass Check	Air Inlet	Check Valve
	1 st Check	2 nd Check***				
PASS <input checked="" type="checkbox"/>						
FAIL <input type="checkbox"/>						
Initial Test	Held at 2.2 psid	Held at 2.2 psid	Opened at	Held at	Opened at	Held at
Date: 11/12/2021	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	psid	Closed Tight <input type="checkbox"/>	Did not open <input type="checkbox"/>	psid
Time: 5:10 pm	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/>)	Leaked <input type="checkbox"/>
Repairs and Materials Used**	Main: Bypass:					
Test After Repair	Held at	Held at	Opened at	Held at	Opened at	Held at
Date:	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>	psid	Closed Tight <input type="checkbox"/>	psid	psid
Time:						

*** 2nd check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: <input checked="" type="checkbox"/>	Non-Potable: <input type="checkbox"/>
Make/Model: Bac Flo 5	SN: 06163433	Date tested for accuracy: 10/11/2021

Remarks:	
----------	--

Company Name:	1st Fire Safety	Licensed Tester Name (Print/Type):	Scott Stevenson
Company Address:	PO Box 1238 Cedar Park, Tx 78613	Licensed Tester Name (Signature):	<i>Scott Stevenson</i>
Company Phone #:	512-777-1555	BPAT License #	BP0017507
		License Expiration Date:	12/21/2022

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS