

Service Address

Hazard/CCID: 42215

# Backflow Prevention Assembly Test Report

SAN MARCOS, TX 78666

Location: 329 Blue Oak Blvd

Meter#:

LID/Service:

Account #:

Serial #: Check if Correct Corrections

HF 93547

Manufacturer:

Febco

Model:

850

Type:

DC

Size:

1"

Orientation:

At meter

Protection:

Irrigation

Test Due No Later than:

Existing  New

Removed  Replaced

Commercial

Industrial

Residential

Municipal

Domestic

Irrigation

Fire

## Reduced Pressure Principle Assembly

### Double Check Valve Assembly

### PVB/SVB

#### Initial Test

Date 4/6/22

Time 5:15pm

Pass  Fail

Leaked

Closed Tight

Held at 2.4 PSID

Leaked

Closed Tight

Held at 2.4 PSID

Did not open

Opened at \_\_\_ PSID

Did not open

Opened Fully Yes

No

Opened at \_\_\_ PSID

Leaked

Held at \_\_\_ PSID

#### Repairs

Date \_\_\_\_\_

Time \_\_\_\_\_

- Cleaned
- Rubber Kit
- Rebuild
- Replaced
- Other

#### Final Test

Date \_\_\_\_\_

Time \_\_\_\_\_

Pass  Fail

Closed Tight

Held at \_\_\_ PSID

Closed Tight

Held at \_\_\_ PSID

Opened at \_\_\_ PSID

Opened Fully

Opened at \_\_\_ PSID

Held at \_\_\_ PSID

#### Air Gap

Date \_\_\_\_\_

Time \_\_\_\_\_

Diameter \_\_\_\_\_

Separation \_\_\_\_\_

Pass  Fail

Comments:

I certify all information on this report is true & accurate, acknowledging that incomplete reports will not be accepted.

Tester Scott Stevenson Signature [Signature]

Certification # BP0017507 Expire 12/21/22 Phone 512-294-3826

Test Kit Serial # 06163433 Calibration Date 10/11/21

Company 1st Fire Safety Phone 512-777-1555

- Proper Installation Yes  No
- RV Exercised Yes  No
- #2 Shutoff Closed Yes  No
- Service Restored Yes  No

Line Pressure 60 psi  
Meter Reading \_\_\_\_\_

Test Results  
Pass  Fail



Submit completed  
Test Report:

630 E HOPKINS ST  
SAN MARCOS TX 78666  
512-393-8008 Fax:  
SODONNELL@SANMARCOSTX.GOV