

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping \*purposes:

NAME OF PWS:	Travis County MUD 12
PWS ID#:	2270403
PWS MAILING ADDRESS:	1502 San Juan Dr Austin, TX 78733
PWS CONTACT PERSON:	Backflow Reports
ADDRESS OF SERVICE:	2405 Sunset Vista Cir. Spicewood, TX 78669

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):**

<input checked="" type="checkbox"/>	Reduced Pressure Principle (RPBA)	<input type="checkbox"/>	Reduced Pressure Principle-Detector (RPBA-D) Type II	<input type="checkbox"/>
<input type="checkbox"/>	Double Check Valve (DCVA)	<input type="checkbox"/>	Double Check-Detector (DCVA-D) Type II	<input type="checkbox"/>
<input type="checkbox"/>	Pressure Vacuum Breaker (PVB)	<input type="checkbox"/>	Spill-Resistant Pressure Vacuum Breaker (SVB)	

Manufacturer:	Main: Febco	Bypass:	Size:	Main: 1"	Bypass:
Model Number:	Main: 860	Bypass:	BPA Location:	Left side of house	
Serial Number:	Main: HA01671	Bypass:	BPA Serves:	Irrigation with OSSF	


Reason for test:	New <input checked="" type="checkbox"/>	Existing <input type="checkbox"/>	Replacement <input type="checkbox"/>	Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?				<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is the assembly installed on a non-potable water supply (auxiliary)?				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

TEST RESULT  PASS <input checked="" type="checkbox"/>  FAIL <input type="checkbox"/>	Reduced Pressure Principle Assembly (RPBA)			Type II Assembly	PVB & SVB	
	DCVA		Relief Valve	Bypass Check	Air Inlet	Check Valve
	1 <sup>st</sup> Check	2 <sup>nd</sup> Check***				
<b>Initial Test</b> Date: 5/6/2022 Time: 9:00AM	Held at <u>0</u> psid Closed Tight <input type="checkbox"/> Leaked <input checked="" type="checkbox"/>	Held at <u>    </u> psid Closed Tight <input type="checkbox"/> Leaked <input checked="" type="checkbox"/>	Opened at <u>    </u> psid Did not open <input type="checkbox"/>	Held at <u>    </u> psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>    </u> psid Did not open <input type="checkbox"/> Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/> )	Held at <u>    </u> psid Leaked <input type="checkbox"/>
Repairs and Materials Used**	Main: Cleaned and flushed Bypass: <u>    </u>					
<b>Test After Repair</b> Date: <u>    </u> Time: <u>    </u>	Held at <u>7.6</u> psid Closed Tight <input checked="" type="checkbox"/>	Held at <u>    </u> psid Closed Tight <input checked="" type="checkbox"/>	Opened at <u>3.5</u> psid	Held at <u>    </u> psid Closed Tight <input type="checkbox"/>	Opened at <u>    </u> psid	Held at <u>    </u> psid

\*\*\* 2<sup>nd</sup> check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: <input checked="" type="checkbox"/>	Non-Potable: <input type="checkbox"/>
Make/Model: MidWest 845	SN: 10150482	Date tested for accuracy: 10/7/2021

Remarks:	
----------	--

Company Name:	Safewater Backflow	Licensed Tester Name (Print/Type):	Brad Weyant
Company Address:	PO Box 4002 Austin, TX 78765	Licensed Tester Name (Signature):	
Company Phone #:	512-605-9790	BPAT License #	BP0016935
		License Expiration Date:	12/3/2024

**The above is certified to be true at the time of testing.**

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS