



Spike @ Jonahwater.com

4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: 2460022

MAILING ADDRESS 401 Flowers Ave  
 CONTACT PERSON Taylor Morrison  
 LOCATION OF SERVICE 401 Flowers Ave  
 INSPECTION DATE 12/12/23 12:25 pm

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo

Model # DUMA Serial # 53781C

Location of device : 12' left of Meter

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker			
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve	
	1st Check	2nd Check		Opened at psid	psid	Held at psid	psid
Initial Test	Held at <u>1.7</u> psid	Held at <u>1.8</u> psid	Opened at psid	psid	Did not Open	psid	Leaked
	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Did not open	psid			
	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>					
Repairs and Materials Used							
Test After	Held at psid	Held at psid	Opened at psid	psid	Opened at psid	psid	Held At psid
Repair	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>					

The above is certified to be true at the time of testing.

Test gauge used: Make / Model Watts TK-99E SN: 574997 Calibration Date: 1/19/23

Firm Name H2Flow  
 Firm Address 100 Antlers Trl, Leander TX, 78641  
 Firm Phone # (512) 259-5296

Certified Tester Thomas Murray Thompson  
 Cert. Tester No. BP0016285

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS