

Backflow Prevention Assembly Test Report

<u>Service Address</u>	Hazard/CCID: 42215	Location: 1429 Blue Oak Blvd. San Marcos, TX 78666	
* SAN MARCOS, TX 78666	Meter#: 96060025 LID/Service: Account #:	Serial #:	Check if Correct <input checked="" type="checkbox"/> Corrections 53468C
Site Use: Hazard: Irrigation		Manufacturer:	<input checked="" type="checkbox"/> Apollo
<u>Mailing Address</u> 1429 Blue Oak Blvd. San Marcos, TX 78666		Model:	<input checked="" type="checkbox"/> DC4A
		Type:	<input checked="" type="checkbox"/> DCVA
		Size:	<input checked="" type="checkbox"/> 1"
		Orientation:	<input checked="" type="checkbox"/> Horizontal
		Protection:	<input checked="" type="checkbox"/> Irrigation - Low

Test Due No Later than:	Existing <input type="checkbox"/> Removed <input type="checkbox"/> New <input checked="" type="checkbox"/> Replaced <input type="checkbox"/>	Commercial <input type="checkbox"/> Industrial <input type="checkbox"/> Residential <input checked="" type="checkbox"/> Municipal <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Fire <input type="checkbox"/>
--------------------------------	---	--	--

Reduced Pressure Principle Assembly	PVB/SVB					
Double Check Valve Assembly						
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%; text-align: center;">Check Valve #1</td> <td style="width: 25%; text-align: center;">Check Valve #2</td> <td style="width: 25%; text-align: center;">Relief Valve</td> <td style="width: 25%; text-align: center;">Air Inlet</td> <td style="width: 25%; text-align: center;">Check Valve</td> </tr> </table>	Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve	
Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve		

Initial Test Date <u>1/19/2024</u> Time <u>12:30PM</u> Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	Leaked <input type="checkbox"/> Closed Tight <input checked="" type="checkbox"/> Held at <u>1.9</u> PSID	Leaked <input type="checkbox"/> Closed Tight <input checked="" type="checkbox"/> Held at <u>2.1</u> PSID	Did not open <input type="checkbox"/> Did not open <input type="checkbox"/> Opened at ____ PSID	Did not open <input type="checkbox"/> Opened Fully Yes <input type="checkbox"/> No <input type="checkbox"/> Opened at ____ PSID	Leaked <input type="checkbox"/> Held at ____ PSID
---	--	--	---	--	--

Repairs Date _____ Time _____	Cleaned <input type="checkbox"/> Rubber Kit <input type="checkbox"/> Rebuild <input type="checkbox"/> Replaced <input type="checkbox"/> Other <input type="checkbox"/>	_____ _____
--	--	----------------

Final Test Date _____ Time _____ Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Closed Tight <input type="checkbox"/> Held at ____ PSID	Closed Tight <input type="checkbox"/> Held at ____ PSID	Opened at ____ PSID	Opened Fully <input type="checkbox"/> Opened at ____ PSID	Held at ____ PSID
--	--	--	---------------------	--	-------------------

Air Gap	Date _____	Time _____	Diameter _____	Separation _____	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
----------------	------------	------------	----------------	------------------	---

Comments: _____ _____ I certify all information on this report is true & accurate, acknowledging that incomplete reports will not be accepted.	<table style="width: 100%;"> <tr> <td>Proper Installation</td> <td>Yes <input checked="" type="checkbox"/></td> <td>No <input type="checkbox"/></td> </tr> <tr> <td>RV Exercised</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>#2 Shutoff Closed</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Service Restored</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Line Pressure</td> <td colspan="2" style="text-align: center;"><u>60</u></td> </tr> <tr> <td>Meter Reading</td> <td colspan="2" style="text-align: center;"><u>3565.56</u></td> </tr> <tr> <td colspan="3" style="text-align: center;">Test Results</td> </tr> <tr> <td>Pass</td> <td><input checked="" type="checkbox"/></td> <td>Fail <input type="checkbox"/></td> </tr> </table>	Proper Installation	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	RV Exercised	<input type="checkbox"/>	<input checked="" type="checkbox"/>	#2 Shutoff Closed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Service Restored	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Line Pressure	<u>60</u>		Meter Reading	<u>3565.56</u>		Test Results			Pass	<input checked="" type="checkbox"/>	Fail <input type="checkbox"/>
Proper Installation	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>																							
RV Exercised	<input type="checkbox"/>	<input checked="" type="checkbox"/>																							
#2 Shutoff Closed	<input checked="" type="checkbox"/>	<input type="checkbox"/>																							
Service Restored	<input checked="" type="checkbox"/>	<input type="checkbox"/>																							
Line Pressure	<u>60</u>																								
Meter Reading	<u>3565.56</u>																								
Test Results																									
Pass	<input checked="" type="checkbox"/>	Fail <input type="checkbox"/>																							
Tester <u>Brad Weyant</u> Signature <u><i>Brad Weyant</i></u> Certification # <u>BP0016935</u> Expire <u>12/3/2024</u> Phone <u>5126059790</u> Test Kit Serial # <u>10150482</u> Calibration Date <u>10/4/2023</u> Company <u>Safewater Backflow</u> Phone <u>5126059790</u>																									

Submit completed Test Report:	630 E HOPKINS ST SAN MARCOS TX 78666 512-393-8008 Fax: SODONNELL@SANMARCOSTX.GOV
----------------------------------	---

