

# City of Pflugerville - PWSID #2270014



## Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping \*purposes

Customer Information		PWS Information	
Customer / Property Name:	<b>Resident</b>	PWS Contact Name:	<b>Aaron Griffith</b>
Contact Name:		PWS Phone Number:	<b>(512) 990-6427</b>
Property Address:	<b>15305 Ollie Briar St Pflugerville, TX 78660</b>	PWS Address:	<b>15500 Sun Light Near Way #B Pflugerville, TX, 78691</b>

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

### Assembly Information

Type:	<b>DC</b>	Model #:	<b>DC4A</b>
Size:	<b>1"</b>	Serial#:	<b>63953C</b>
Manufacturer:	<b>Apollo</b>	BPA Serves:	<b>Irrigation</b>
Location:	<b>Left Frony Yard 5' From Meter</b>		

Reason for test: [ ] new [X] existing [ ] replaced.  
 Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [ ] no  
 Water supply: Potable

# PASS

Test Date: 2024-02-09

### Assembly Test Information

Initial Test ( Time: 02:30 pm )	
Check Valve #1 : 1.5 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 1.8 (X) Closed Tight/Held ( ) Leaked
Final Test	
Check Valve #1 : 1.5 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 1.8 (X) Closed Tight/Held ( ) Leaked

As the tester of record, I affirm this test as: Passed [X] Failed [ ] **Repairs Made:\*\* No**

Additional comments or repairs made / materials (parts) used:  
**( no comments )**

### Tester Information

Tester Name:	<b>Weyant, Brad</b>
Tester License Expiration:	<b>12-03-2024</b>
Certification#:	<b>BP0016935</b>
Test Kit Serial #:	<b>10150482</b>
Test Kit Date Tested for Accuracy:	<b>10-05-2023</b>
Test Kit Mfr. & Mod. #:	<b>Mid-West 845-5 (Potable)</b>
Testing Co Name:	<b>Safewater Backflow and Irrigation</b>
Phone:	<b>(512) 605-9790</b>
Address:	<b>PO Box 4002 Austin, TX 78765</b>

The above tester certifies that all information submitted for this report is true and accurate  
\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters