

PHYSICAL ADDRESS
 201-B EAST PECAN ST
 PFLUGERVILLE, TEXAS 78660
 PHONE: (512) 990-6320
 FAX: (512) 990-4374



MAILING ADDRESS
 BUILDING DEPARTMENT
 PO BOX 589 / 78691
 PFLUGERVILLE, TEXAS 78660

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. **DO NOT LEAVE THIS REPORT IN METER BOX**
 A signed and dated **ORIGINAL** must be submitted to the public water supplier.

ILLEGAL OR INCOMPLETE REPORTS WILL NOT BE ACCEPTED

RESIDENTIAL _____ COMMERCIAL _____

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes

BACKFLOW ASSEMBLY INFORMATION

Serial Number HG35085 Manufacturer Febco Model 850 Size 1"

Occupant/Business Name Taylor Morrison

Physical Address 2105 Grand Leeanne Way

Assembly Location on Property 8ft past meter towards house

Purpose of Assembly Irrigation

CUSTOMER INFORMATION

Property Owner/Agent Taylor Morrison

Mailing Address 2105 Grand Leanne Way Bldg. _____ Suite# _____

City Pflugerville State TX Zip Code 78660

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle Detector
- Double Check Detector
- Spill-Resistant Pressure Vacuum Breaker

	REDUCED PRESSURE BACKFLOW PREVENTION ASSEMBLY		PRESSURE VACUUM BREAKER		
	DOUBLE-CHECK VALVE ASSEMBLY		RELIEF VALVE	AIR INLET	CHECK VALVE
	1ST CHECK	2ND CHECK			
INITIAL TEST	Held at <u>2.2</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.3</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
TEST AFTER REPAIRS	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid
REPAIRS AND MATERIALS USED					

Test gauge used: Make/Model: Mid West 845 SN: 10150482 Calibration Date: 10/5/2022

Remarks: 2:15PM

The above is certified to be true at the time of testing.

CERTIFICATION # BP0016935 GAUGE SERIAL # 10150482

PHONE 512-605-9790 BACKFLOW TECHNICIAN Brad Weyant

DATE 3/6/2023 TECHNICIAN'S SIGNATURE Brad Weyant

***TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS. **USE ONLY MANUFACTURER'S REPLACEMENT PARTS.**