



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: **2460022**

MAILING ADDRESS 207 Oconee St. Hutto, TX 78634

CONTACT PERSON Taylor Morrison

LOCATION OF SERVICE 207 Oconee St. Hutto, TX 78634

INSPECTION DATE 2/15/2024 10:40AM

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- ( X ) Reduced Pressure ZONE
- ( ) Double Check Valve
- ( ) Pressure Vacuum Breaker
- ( ) Reduced Pressure Principle-Detector
- ( ) Double Check-Detector
- ( ) Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo \_\_\_\_\_

Model # DC4A \_\_\_\_\_ Serial # 64150C \_\_\_\_\_

Location of device Left front yard 5 feet from meter

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes \_\_\_\_\_

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check		Opened at psid	Held at psid
Initial Test	Held at 1.8 Psi	Held at psid 1.9	Opened at psid	Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Did not open <input type="checkbox"/>		
Repairs and Materials Used					
Test After Repair	Held at psid <input type="checkbox"/> Closed Tight	Held at psid <input type="checkbox"/> Closed Tight	Opened at psid	Opened at psid	Held At psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 10150482 Calibration Date: 10/4/2023

Firm Name Safewater Backflow Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765 Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

**- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS**