Texas Commission on Environmental Quality

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes: NAME OF PWS: Dripping Springs WSC PWS ID#: 1050013 **PWS MAILING ADDRESS:** 101 Hays St. Ste. 406 Dripping Springs, TX 78620 PWS CONTACT PERSON: Cory Taylor ADDRESS OF SERVICE: 120 Milkwood Ter. Dripping Springs, TX 787620 The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters. TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA): Reduced Pressure Principle (RPBA) Type II Reduced Pressure Principle-Detector (RPBA-D) \boxtimes Double Check Valve (DCVA) Double Check-Detector (DCVA-D) Type II Pressure Vacuum Breaker (PVB) Spill-Resistant Pressure Vacuum Breaker (SVB) Manufacturer: Main: Apollo Bypass: Size: Main: 1" Bypass: Main: DC4A Right front yard 5 feet from meter Bypass: **BPA** Location: Model Number: Main: 53425C Bypass: Irrigation Serial Number: **BPA Serves:** Reason for test: New 🛛 Existing Replacement Old Model/Serial # Is the assembly installed in accordance with manufacturer recommendations and/or local codes? ⊠ Yes □ No Is the assembly installed on a non-potable water supply (auxiliary)? No. ☐ Yes **TEST RESULT** Type II Reduced Pressure Principle Assembly (RPBA) Assembly PVB & SVB PASS 🛛 **DCVA** Relief Valve Bypass Check Air Inlet Check Valve FAIL 🗆 2nd Check*** 1st Check Held at 1.9 psid Held at 1.9 psid Opened at psid Opened at psid Held at **Initial Test** Held at Did not psid Date: psid Closed Tight Closed Tight Closed Tight Did not 10/10/2023 open Did it Leaked Leaked Leaked Leaked open 🔲 Time: 2:30PM fully open (Yes \square /No 🔲) Repairs and Main: Materials Used** Bypass: psid Held at Test After Held at psid Held at Opened at psid Opened at psid Held at Closed Repair Closed Tight | Closed Tight | psid psid Date: Tight | Time: *** 2nd check: numeric reading required for DCVA only Differential pressure gauge used: Potable: Non-Potable: Make/Model: MidWest 845 SN: 10150482 Date tested for accuracy: 10/4/2023 Remarks: Company Name: Safewater Backflow Licensed Tester Name (Print/Type): Company Address: PO Box 4002 Austin, TX 78765 Licensed Tester Name (Signature): BPAT License # Company Phone #: BP0016935 512-605-9790 License Expiration Date:

The above is certified to be true at the time of testing.

^{*} TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

^{**} USE ONLY MANUFACTURER'S REPLACEMENT PARTS