

City of Pflugerville - PWSID #2270014



Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

Customer Information

Customer / Property Name: **Resident**
Contact Name:
Property Address: **15320 Holloway Dr
Pflugerville, TX 78660**

PWS Information

PWS Contact Name: **Aaron Griffith**
PWS Phone Number: **(512) 990-6427**
PWS Address: **15500 Sun Light Near Way #B
Pflugerville, TX, 78691**

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

Type: **DC** Model #: **DC4A**
Size: **1"** Serial#: **52876C**
Manufacturer: **Apollo** BPA Serves: **Irrigation**
Location: **Left front yard 5 feet from meter**
Reason for test: new existing replaced.
Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes no
Water supply: Potable

PASS

Test Date: 2023-10-02

Assembly Test Information

Initial Test (Time: 12:00 pm)	
Check Valve #1 : 1.4 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.3 (X) Closed Tight/Held () Leaked
Final Test	
Check Valve #1 : 1.4 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.3 (X) Closed Tight/Held () Leaked

As the tester of record, I affirm this test as: Passed Failed **Repairs Made:** No**

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: **Weyant, Brad**
Tester License Expiration: **12-03-2024**
Certification#: **BP0016935**
Test Kit Serial #: **10150482**
Test Kit Date Tested for Accuracy: **10-05-2022**
Test Kit Mfr. & Mod. #: **Mid-West 845-5 (Potable)**
Testing Co Name: **Safewater Backflow and Irrigation**
Phone: **(512) 605-9790**
Address: **PO Box 4002
Austin, TX 78765**

Custom Questions

Is the assembly installed in accordance with manufacturer recommendations and / or local codes? Y/N
Y
Bypass identifying information (manufacturer, model, serial number, and size)

The above tester certifies that all information submitted for this report is true and accurate

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters