1696356624_8202_53091C.pdf

Open with Google Docs

City of Pflugerville - PWSID #2270014



The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

Customer Information	
Customer / Property Name:	Resident
Contact Name:	
Property Address:	1700 Carvin Way
	Dflumomille TV 79660

Pflugerville, TX 78660

PWS Contact Name: Aaron Griffith PWS Phone Number: (512) 990-6427 15500 Sun Light Near Way #B Pflugerville, TX, 78691

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

PWS Information

PWS Address:

Assembly Information			
Туре:	DC	Model #:	DC4A PASS
Size:	1"	Serial#:	53091C
Manufacturer:	Apollo	BPA Serves:	Irrigation
Location: Right front yard 5 feet from meter			Test Date: 2023-10-02
Reason for test: [X] new [1 existing [1 replaced.		

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no Water supply: Potable

Assembly Test Information

Check Valve #1 : 1.7	Check Valve #2 : 1.7
(X) Closed Tight/Held() Leaked	(X) Closed Tight/Held () Leaked
Final Test	
Check Valve #1 : 1.7	Check Valve #2 : 1.7
(X) Closed Tight/Held() Leaked	(X) Closed Tight/Held () Leaked

As the tester of record, I affirm this test as: Passed [X] Failed [] Repairs Made:** No

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information		
Tester Name: Tester License Expiration:	Weyant, Brad 12-03-2024	Custom Questions
Certification#:	BP0016935	Is the assembly installed in accordance with
Test Kit Serial #: Test Kit Date Tested for Accuracy:	10150482 10-05-2022	manufacturer recommendations and / or local codes? Y/N
Test Kit Mfr. & Mod. #:	Mid-West 845-5 (Potable)	Y
Testing Co Name: Phone:	Safewater Backflow and Irrigation (512) 605-9790	Bypass identifying information (manufacturer, model, serial number, and size)
Address:	PO Box 4002	model, senai number, and size)
	Austin, TX 78765	

The above tester certifies that all information submitted for this report is true and accurate
* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]
** USE ONLY MANUFACTURER'S REPLACEMENT PARTS
The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within
acceptable parameters

Page 1 of 1