City of Pflugerville - PWSID #2270014

Backflow Prevention Assembly Test and Maintenance Report



The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

| Customer Information | | PWS Information | |
|---------------------------|---|-------------------|--|
| Customer / Property Name: | Resident | PWS Contact Name: | Aaron Griffith |
| Contact Name: | | PWS Phone Number: | (512) 990-6427 |
| Property Address: | 1615 Purple Martin Dr Pflugerville, TX 78660 | PWS Address: | 15500 Sun Light Near Way #B Pflugerville, TX, 78691 |

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

| Туре: | DC | Model #: | DC4A P | ASS |
|---------------------------|--|-------------------------|---------------------|----------------------|
| Size: | 1" | Serial#: | 52991C | |
| Manufacturer: | Apollo | BPA Serves: | Irrigation _ | |
| Location: | left front yard 5 ft from meter | | Test Dat | e: 2024-04-18 |
| Reason for test: [X] new | [] existing [] replaced. | | | |
| la tha accomply installes | Lin apportance with manufacturer recommo | ndations and/or local a | adaa2 [V] yaa [] na | |

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no Water supply: Potable

Assembly Test Information

| Initial Test (Time: 12:20 pm) | | |
|--|--|--|
| Check Valve #1 : 1.9 | Check Valve #2 : 1.8 | |
| (X) Closed Tight/Held() Leaked | (X) Closed Tight/Held() Leaked | |
| Final Test | | |
| Check Valve #1 : 1.9 | Check Valve #2 : 1.8 | |
| (X) Closed Tight/Held() Leaked | (X) Closed Tight/Held() Leaked | |

As the tester of record, I affirm this test as: Passed [X] Failed [] Repairs Made:** No

Additional comments or repairs made / materials (parts) used:

(no comments)

| Tester Information | |
|------------------------------------|-----------------------------------|
| Tester Name: | Weyant, Brad |
| Tester License Expiration: | 12-03-2024 |
| Certification#: | BP0016935 |
| Test Kit Serial #: | 09231317 |
| Test Kit Date Tested for Accuracy: | 03-14-2024 |
| Test Kit Mfr. & Mod. #: | Mid-West 845-5 (Potable) |
| Testing Co Name: | Safewater Backflow and Irrigation |
| Phone: | (512) 605-9790 |
| Address: | PO Box 4002 |
| | Austin, TX 78765 |

The above tester certifies that all information submitted for this report is true and accurate

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters