

# City of Pflugerville - PWSID #2270014



## Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping \*purposes

Customer Information	PWS Information
Customer / Property Name: <b>Resident</b>	PWS Contact Name: <b>Aaron Griffith</b>
Contact Name:	PWS Phone Number: <b>(512) 990-6427</b>
Property Address: <b>1628 Alana Falls Ave Pflugerville, TX 78660</b>	PWS Address: <b>15500 Sun Light Near Way #B Pflugerville, TX, 78691</b>

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

### Assembly Information

Type:	<b>DC</b>	Model #:	<b>850</b>
Size:	<b>1"</b>	Serial#:	<b>HG21368</b>
Manufacturer:	<b>Febco</b>	BPA Serves:	<b>Irrigation</b>
Location:	<b>left front yard 5 feet from meter</b>		

Reason for test:  new  existing  replaced.  
 Is the assembly installed in accordance with manufacturer recommendations and/or local codes?  yes  no  
 Water supply: Potable

# PASS

Test Date: 2023-04-04

### Assembly Test Information

Initial Test ( Time: 01:30 pm )	
Check Valve #1 : 2.4 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 2.7 (X) Closed Tight/Held ( ) Leaked
Final Test	
Check Valve #1 : 2.4 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 2.7 (X) Closed Tight/Held ( ) Leaked

As the tester of record, I affirm this test as: Passed  Failed  **Repairs Made:\*\* No**

Additional comments or repairs made / materials (parts) used:  
**( no comments )**

### Tester Information

Tester Name:	<b>Weyant, Brad</b>	Custom Questions
Tester License Expiration:	<b>12-03-2024</b>	<b>Is the assembly installed in accordance with manufacturer recommendations and / or local codes? Y/N</b>
Certification#:	<b>BP0016935</b>	
Test Kit Serial #:	<b>10150482</b>	Y
Test Kit Date Tested for Accuracy:	<b>10-05-2022</b>	<b>Bypass identifying information (manufacturer, model, serial number, and size)</b>
Test Kit Mfr. & Mod. #:	<b>Mid-West 845-5 (Potable)</b>	
Testing Co Name:	<b>Safewater Backflow and Irrigation</b>	
Phone:	<b>(512) 605-9790</b>	
Address:	<b>PO Box 4002 Austin, TX 78765</b>	

The above tester certifies that all information submitted for this report is true and accurate  
\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters