

Texas Commission on Environmental Quality
BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

| | |
|----------------------|---|
| NAME OF PWS: | Round Rock Water |
| PWS ID#: | 2460003 |
| PWS MAILING ADDRESS: | 3400 Sunrise Rd Round Rock, TX 78665 |
| PWS CONTACT PERSON: | Inspections |
| ADDRESS OF SERVICE: | 1843 Homestead Farms Drive Round Rock, TX 78681 |

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

| | | | | |
|-------------------------------------|-----------------------------------|--------------------------|---|----------------------------------|
| <input type="checkbox"/> | Reduced Pressure Principle (RPBA) | <input type="checkbox"/> | Reduced Pressure Principle-Detector (RPBA-D) | Type II <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | Double Check Valve (DCVA) | <input type="checkbox"/> | Double Check-Detector (DCVA-D) | Type II <input type="checkbox"/> |
| <input type="checkbox"/> | Pressure Vacuum Breaker (PVB) | <input type="checkbox"/> | Spill-Resistant Pressure Vacuum Breaker (SVB) | |

| | | | | | |
|----------------|--------------|---------|---------------|------------------------------------|---------|
| Manufacturer: | Main: Apollo | Bypass: | Size: | Main: 1" | Bypass: |
| Model Number: | Main: DC4A | Bypass: | BPA Location: | Right front yard 5 feet from meter | |
| Serial Number: | Main 94105C | Bypass: | BPA Serves: | Irrigation | |


| | | | | |
|---|---|-----------------------------------|--------------------------------------|---|
| Reason for test: | New <input checked="" type="checkbox"/> | Existing <input type="checkbox"/> | Replacement <input type="checkbox"/> | Old Model/Serial # |
| Is the assembly installed in accordance with manufacturer recommendations and/or local codes? | | | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Is the assembly installed on a non-potable water supply (auxiliary)? | | | | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |

| TEST RESULT | Reduced Pressure Principle Assembly (RPBA) | | | Type II Assembly | PVB & SVB | |
|--|---|---|---|--|---|---|
| | DCVA | | Relief Valve | Bypass Check | Air Inlet | Check Valve |
| | 1st Check | 2nd Check*** | | | | |
| PASS <input checked="" type="checkbox"/> | | | | | | |
| FAIL <input type="checkbox"/> | | | | | | |
| Initial Test Date: 10/9/2024 Time: 9:10AM | Held at 1.7 psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/> | Held at 1.9 psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/> | Opened at ___ psid Did not open <input type="checkbox"/> | Held at ___ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/> | Opened at ___ psid Did not open <input type="checkbox"/> Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/>) | Held at ___ psid Leaked <input type="checkbox"/> |
| Repairs and Materials Used** | Main: Bypass: | | | | | |
| Test After Repair Date: Time: | Held at ___ psid Closed Tight <input type="checkbox"/> | Held at ___ psid Closed Tight <input type="checkbox"/> | Opened at ___ psid | Held at ___ psid Closed Tight <input type="checkbox"/> | Opened at ___ psid | Held at ___ psid |

*** 2nd check: numeric reading required for DCVA only

| | | |
|-----------------------------------|--|---------------------------------------|
| Differential pressure gauge used: | Potable: <input checked="" type="checkbox"/> | Non-Potable: <input type="checkbox"/> |
| Make/Model: Mid West 845 | SN: 09231317 | Date tested for accuracy: 3/14/2024 |

| | |
|----------|---------|
| Remarks: | Permit# |
|----------|---------|

| | | | |
|------------------|------------------------------|------------------------------------|---|
| Company Name: | Safewater Backflow | Licensed Tester Name (Print/Type): | Brad Weyant |
| Company Address: | PO Box 4002 Austin, TX 78765 | Licensed Tester Name (Signature): |  |
| Company Phone #: | 512-605-9790 | BPAT License # | BP0016935 |
| | | License Expiration Date: | 12/3/2024 |

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS