

pfluTexas Commission on Environmental Quality  
**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping \*purposes:

NAME OF PWS:	Pflugerville Water
PWS ID#:	2270014
PWS MAILING ADDRESS:	100 E Main St Pflugerville, TX 78660
PWS CONTACT PERSON:	Backflow Inspections
ADDRESS OF SERVICE:	1912 Bradham Way Pflugerville TX 78660

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):**

<input type="checkbox"/>	Reduced Pressure Principle (RPBA)	<input type="checkbox"/>	Reduced Pressure Principle-Detector (RPBA-D)	Type II <input type="checkbox"/>
<input checked="" type="checkbox"/>	Double Check Valve (DCVA)	<input type="checkbox"/>	Double Check-Detector (DCVA-D)	Type II <input type="checkbox"/>
<input type="checkbox"/>	Pressure Vacuum Breaker (PVB)	<input type="checkbox"/>	Spill-Resistant Pressure Vacuum Breaker (SVB)	

Manufacturer:	Main: Apollo	Bypass:	Size:	Main: 1"	Bypass:
Model Number:	Main: DC4A	Bypass:	BPA Location:	Right front yard 10 feet from meter	
Serial Number:	Main 89024C	Bypass:	BPA Serves:	Irrigation	


Reason for test:	New <input checked="" type="checkbox"/>	Existing <input type="checkbox"/>	Replacement Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is the assembly installed on a non-potable water supply (auxiliary)?			<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

TEST RESULT	Reduced Pressure Principle Assembly (RPBA)			Type II Assembly	PVB & SVB	
	DCVA		Relief Valve	Bypass Check	Air Inlet	Check Valve
	1st Check	2nd Check***				
<b>PASS</b> <input checked="" type="checkbox"/>						
<b>FAIL</b> <input type="checkbox"/>						
<b>Initial Test</b> Date: 7/22/2024 Time: 3:45PM	Held at 1.9 psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at 2.0 psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Held at ___ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/> Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/>	Held at ___ psid Leaked <input type="checkbox"/>
Repairs and Materials Used**	Main:  Bypass:					
<b>Test After Repair</b> Date: Time:	Held at ___ psid Closed Tight <input type="checkbox"/>	Held at ___ psid Closed Tight <input type="checkbox"/>	Opened at ___ psi	Held at ___ psid Closed Tight <input type="checkbox"/>	Opened at ___ psid	Held at ___ psid

\*\*\* 2nd check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: <input checked="" type="checkbox"/>	Non-Potable: <input type="checkbox"/>
Make/Model: MidWest 845	SN: 09231317	Date tested for accuracy: 3/14/2024

Remarks:	

Company Name:	Safewater Backflow	Licensed Tester Name (Print/Type):	Brad Weyant
Company Address:	PO Box 4002 Austin, TX 78765	Licensed Tester Name (Signature):	
Company Phone #:	512-605-9790	BPAT License #	BP0016935
		License Expiration Date:	12/3/2024

**The above is certified to be true at the time of testing.**

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS