Service Address	Backflow Prevention Assembly Test Report				
* Location: 224 Chaste Tree Dr. San Marcos, TX 78666					
SAN MARCOS, T	X 78666	Meter#: 96225326 LID/Service:	S Se	erial #: Check if	F Correct Corrections 53392C
		Account #:		Apollo Apollo	
Site Use: Hazard: Irrigation			Mo	odel:	凶 <sup>DC4A</sup>
Mailing Address			Ту	rpe:	<b>⊠</b> DCVA
224 Chaste Tree Dr.			Siz	ze:	⊠ <u>1"</u>
San Marcos, TX 78666			Or	rientation:	
			_		⊠ Horizontal
			Pr	otection:	
Fest Due No Later than		moved Commercial C	Industrial Residentia	l 🕅 Municipal 🔲	Domestic Irrigation X Fire
Reduced Pressure Principle Assembly					
Double Check V		ve Assembly			PVB/SVB
	Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve
nitial Test Date 6/25/2024	Leaked  Closed Tight	Leaked  Closed Tight	Did not open	Did not open Opened Fully Y	es Leaked
Γime <u>2:20PM</u> Pass <b>⊠</b> fail □	Held at 1.7 PSID	Held at 1.8 PSID	Opened at PSID	Opened at F	
Repairs  Date	Cleaned				
Final Test  Date	Closed Tight	Closed Tight		Opened Fully	
Time Pass	Held at PSID	Held at PSID	Opened at PSID	Opened at F	PSID Held at PSID
Air Gap	Date	Time	Diameter	Separation	Pass
Comments:					Proper Installation Yes No
I certify all information on this report is true & accurate, acknowledging that incomplete reports will not be accepted.					Proper Installation  RV Exercised  #2 Shutoff Closed Service Restored
Tester BR010005					
BP001 Certification #	6935 Ex	Expire 12/3/2024 Phone 5126059790			Meter Reading 3599.16
Test Kit Serial #					
Company Safewater Backflow Phone 5126059790 Pass Safewater Backflow					
630 E HOPKINS ST					



Submit completed Test Report:

SAN MARCOS TX 78666 512-393-8008 Fax: SODONNELL@SANMARCOSTX.GOV