



Spike @ Jonahwater.com

4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: 2460022

MAILING ADDRESS 307 Doodle Ln
 CONTACT PERSON Taylor Morrison
 LOCATION OF SERVICE 307 Doodle Ln
 INSPECTION DATE 10/17/23

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo

Model # Dc4A Serial # 52875C

Location of device : 7' Right of Meter

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes

| | Reduced Pressure Principle Assembly | | | Pressure Vacuum Breaker | | |
|----------------------------|-------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|---------------------------------------|---------------------------------------|---------------------------------|-------------|
| | Double Check Valve Assembly | | Relief Valve | Air Inlet | | Check Valve |
| | 1st Check | 2nd Check | | Opened at psid | Held at psid | |
| Initial Test | Held at <u>1.9</u> psid | Held at <u>2.0</u> psid | Opened at psid | Did not Open <input type="checkbox"/> | Leaked <input type="checkbox"/> | |
| | Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/> | Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/> | Did not open <input type="checkbox"/> | | | |
| Repairs and Materials Used | | | | | | |
| Test After Repair | Held at psid Closed Tight <input type="checkbox"/> | Held at psid Closed Tight <input type="checkbox"/> | Opened at psid | Opened at psid | Held At psid | |

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Watts TK-99E SN: 574997 Calibration Date: 1/19/23

Firm Name H2Flow
 Firm Address 100 Antlers Trl, Leander TX, 78641
 Firm Phone # (512) 259-5296

Certified Tester Thomas Murray Rumburg
 Cert. Tester No. BP0016285

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS