


# 5160 N AW GRIMES BLVD **UNIT 148**

#### Recommended Maintenance

- Backflow Test Annually
- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads
- Controller Seasonal update programming
- Winter Run system briefly every 2 weeks if system turned off

NOTE: ALL Piping shown is diagrammatic and NOT illustrating actual location.

This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.



#### Recommended Run Times (minutes)

	C Ch h	4.2
	Spray – Shrub	12
•	Spray – Lawn	25
•	Rotor – Lawn	45
•	Drip – Lawn	45

#### **Recommended Monthly Cycles**

(Water Days)

- January February 3
- 4 March
- April
- 7 Mav
- June 9
- July 11
- 11 August
- September October 6
- November 4
- December

## **Legend**

- **Backflow**
- **Control Valve**
- Spray Shrub
- Spray Lawn
- **Rotor Lawn**
- **Drip Tubing**
- **Main Line**

### **COMPLETION ITEMS PROVIDED**

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.



BEST OF TEXAS LANDSCAPES

(512) 260-1430

www.bestoftexaslandscapes.com

RRIGATION PLAN

5160 N AW GRIMES BLVD GEORGETOWN TX 78665 **ERAVISTA CONDOS** 

COMPLETION: 7/15/2021

2021 - 03 / 21

78665NAW5160148

DRAWN BY:

**SINCLAIR** 

CHECKED BY:

**STUBBLEFIELD** 

SCALE:

1" = 10' SHEET: