
Recommended Run Times (minutes)

Spray - Shrub 12 Spray - Lawn 25 45 Rotor - Lawn 45 Drip - Lawn





Recommended Monthly Cycles

(Water Days)

3 January **February** 3 4 March April 7 May June 11 July 11 August

September 9 October 6

November 4 December 3

Recommended Maintenance


- Backflow Test Annually
- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads
- Valve Covers Trim grass to keep exposed
- Controller Seasonal update programming
- Winter Run system briefly every 2 weeks if system turned off

Legend

- <u></u> **Backflow**
- 3 **Control Valve**
- Spray Shrub
- Spray Lawn
- Rotor Lawn
- **Drip Tubing**
- **Main Line**

COMPLETION ITEMS PROVIDED

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.



5612 SEAN PAUL LANE





This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.

System Owner / Representative

Date

NOTE: ALL Piping shown is diagrammatic and NOT illustrating actual location.

SHEET 1" = 20'

4.26.2024 JOB NUMBER: 78641SEA5612 CHECKED BY: DRAWN BY: STUBBLEFIELD STUBBLEFIELD

COMPLETION 05/14/24

PROJECT: 5612 SEAN PAUL LANE GEORGETOWN, TX 78641

LOT 20, BLOCK B PARKSIDE PENINSULA



Company Name Address City, State 12345 (123) 456-7890