

Backflow Prevention Assembly Test Details



Test and Maintenance Report

Water System ID# 2270001

Special Services Division
3907 South Industrial DR
Austin, TX 78744-1070

Phone: (512) 972-1060
FAX: (512) 972-1260



*** Test records must be kept by the customer for at least three years ***

Backflow Assembly Information

Serial Number:	85616C	Manufacturer:	APOLLO/CONBRACO
Model:	DC4A	Size:	1
Service Address:	6514 TURNER COACH TRL 78610		
Assembly location on the property:	AT METER - FRONT LEFT		
Reason the assembly is installed:	IRRIGATION W/ CITY POTABLE WATER		
Is this assembly installed to code requirements?	Yes		

Customer Information

Property Owner / Agent:	HOME OWNER
Mailing Address:	6514 TURNER COACH TRAIL
City / State / Zip:	BUDA, TX 78610
Phone:	

Backflow Test

Initial Test	DCVA	
	Check Valve #1	Check Valve #2
	2.4 PSID	2 PSID
Repairs		
Test After Repairs		
Test Date:	Jun 18, 2024	
Backflow Test Status:	Passed	

Tester Information

The backflow technician listed below has previously certified that the information on this report was true and correct on the date of this test.

Backflow Technician:	STEVENSON, SCOTT
License:	BP0017507
Gauge Serial Number:	06163433