Service Address	Hazard/CCID:		Backflow Prevent	•	est Report	
* Location: 125 Bigtooth Maple Lane San Marcos, TX 78666						
SAN MARCOS, T	X 78666	Meter#: 96225650 LID/Service:	) Se	erial #: Check if Correc	ct Corrections 97956C	
Account #:		Account #:	Ma	anufacturari	Apollo	
Site Use: Hazard: Irrigation			Мо	lodel: DC4A		
Mailing Address			Ту	/pe:	DCVA	
125 Bigtooth N	•		Siz	ze:	1"	
San Marcos, TX 78666			Or	Orientation:     Horizontal		
l			Pr	rotection:	Irrigation - Low	
Test Due No Later than:    Existing						
Reduced Pressure Principle Assembly						
	Double Check Valve Assembly			PVB/SVB		
	Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve	
Initial Test Date 10-31-24	Leaked  Closed Tight	Leaked  Closed Tight	Did not open	Did not open  Opened Fully Yes	Leaked	
Time <u>10:35AM</u> Pass <b>⊠</b> fail □	Held at 2.0 PSID	Held at 2.3 PSID	Opened at PSID	No D Opened at PSID	Held at PSID	
Repairs	Cleaned					
Date	Rubber Kit					
Time	Replaced U					
Final Test  Date	Closed Tight	Closed Tight		Opened Fully		
Time Pass ☐Fail ☐	Held at PSID	Held at PSID	Opened at PSID	Opened at PSID	Held atPSID	
Air Gap	Date	Time	Diameter	Separation	Pass	
Comments:	<u> </u>				Yes No er Installation	
					xercised \Bigcup \Bigc	
I certify all information on this report is true & accurate, acknowledgin <b>g</b> that incomplete reports <u>will</u> not be accepted.					nutoff Closed	
Tester_Brad Weya	Brad Weyant B / W /					
BP0016935 Expire 12/3/2024		tpire 12/3/2024 Ph	Phone 5126059790		Pressure 4121.61	
Test Kit Serial #					Test Results	
Company Safewater Backflow Phone 5126059790 Page Page Page Page Page Page Page Page					ass ⊠ Fail 🗌	



Submit completed Test Report: 630 E HOPKINS ST

SAN MARCOS TX 78666 512-393-8008 Fax:

SODONNELL@SANMARCOSTX.GOV