



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: 2460022  
 MAILING ADDRESS 204 Makinaw, Hutto, TX 78634  
 CONTACT PERSON Taylor Morrison Homes  
 LOCATION OF SERVICE 204 Makinaw, Hutto, TX 78634  
 INSPECTION DATE 06/11/2024 3:55 pm

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure ZONE
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo

Model # DC4A Serial # 53649C

Location of device : At meter - Front Left

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? \_\_\_\_\_

	Reduced Pressure Principle Assembly				Pressure Vacuum Breaker			
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve		
	1st Check	2nd Check		Opened at	psid	Held at	psid	
Initial Test	Held at <u>2.0</u> psid	Held at <u>2.2</u> psid	Opened at	psid	Did not Open	<input type="checkbox"/>	Leaked	<input type="checkbox"/>
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Did not open	<input type="checkbox"/>				
Repairs and Materials Used								
Test After Repair	Held at <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Held at <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Opened at	psid	Opened at	psid	Held At	psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Bac Flo 5 SN: 06163433 Calibration Date: 10/11/23

Firm Name Safety Plus Services, LLC  
 Firm Address 102 Wonder World Drive #304-522 San Marcos, TX 78666

Certified Tester Scott Stevenson  
 Cert. Tester No. BP0017507

Firm Phone # 512-300-9659

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS