



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: **2460022**  
 MAILING ADDRESS \_\_ 4000 Vanderscile Road Hutto, TX 78634 \_\_\_\_\_  
 CONTACT PERSON \_\_ Taylor Morrison \_\_\_\_\_  
 LOCATION OF SERVICE 4000 Vanderscile Road Hutto, TX 78634 \_\_\_\_\_  
 INSPECTION DATE \_11/11/2024\_ 11:45AM \_\_\_\_\_

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- |  |  |
|--|--|
| <input type="checkbox"/> Reduced Pressure ZONE         | <input type="checkbox"/> Reduced Pressure Principle-Detector     |
| <input checked="" type="checkbox"/> Double Check Valve | <input type="checkbox"/> Double Check-Detector                   |
| <input type="checkbox"/> Pressure Vacuum Breaker       | <input type="checkbox"/> Spill-Resistant Pressure Vacuum Breaker |

Manufacturer: Apollo \_\_\_\_\_

Model # DC4A \_\_\_\_\_ Serial # 00177D \_\_\_\_\_

Location of device Right front yard 5 feet from meter \_\_\_\_\_

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes \_\_\_\_\_

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker		
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve
	1st Check	2nd Check		Opened at psid	Held at psid	
Initial Test	Held at 1.9 Closed Tight X Leaked □	Held at psid 2.0 Closed Tight X Leaked □	Opened at psid Did not open □	Did not Open □	Leaked □	
Repairs and Materials Used						
Test After Repair	Held at psid Closed Tight □	Held at psid Closed Tight □	Opened at psid	Opened at psid	Held At psid	

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 09231317 Calibration Date:3/14/2024

Firm Name Safewater Backflow

Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765

Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

**- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS**