



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: **2460022**
 MAILING ADDRESS 4002 Vanderscile Road Hutto, TX 78634
 CONTACT PERSON Taylor Morrison
 LOCATION OF SERVICE 4002 Vanderscile Road Hutto, TX 78634
 INSPECTION DATE 11/13/2024 11:00AM

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- Reduced Pressure ZONE
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo _____

Model # DC4A _____ Serial # 97920C _____

Location of device Left front yard 5 feet from meter _____

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes _____

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker		
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve
	1st Check	2nd Check		Opened at psid	Held at psid	
Initial Test	Held at 1.8	Held at psid 1.9	Opened at psid	Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>	
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Did not open <input type="checkbox"/>			
Repairs and Materials Used						
Test After Repair	Held at psid <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Held at psid <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Opened at psid	Opened at psid	Held At psid	

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 09231317 Calibration Date: 3/14/2024

Firm Name Safewater Backflow

Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765

Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS