

Texas Commission on Environmental Quality
BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	Aqua Water Supply Corporation
PWS ID#:	110013
PWS MAILING ADDRESS:	415 Old Austin Hwy., Bastrop TX 78602
PWS CONTACT PERSON:	SUE DURANGO (512)581-3363 opt 2 compliance@aquawsc.com
ADDRESS OF SERVICE:	105 Booted Eagle Claw Cove, Cedar Crekk, TX 78612

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

<input checked="" type="checkbox"/>	Reduced Pressure Principle (RPBA)	<input type="checkbox"/>	Reduced Pressure Principle-Detector (RPBA-D)
<input type="checkbox"/>	Double Check Valve (DCVA)	<input type="checkbox"/>	Double Check-Detector (DCVA-D)
<input type="checkbox"/>	Pressure Vacuum Breaker (PVB)	<input type="checkbox"/>	Spill-Resistant Pressure Vacuum Breaker (SVB)

Manufacturer:	Febco	Size:	1"
Model Number:	860	BPA Location:	Front right - 6' from the meter
Serial Number:	HA30484	BPA Serves:	Irrigation - City Potable with OSSF

Reason for test:	New <input checked="" type="checkbox"/>	Existing <input type="checkbox"/>	Replacement <input type="checkbox"/>	Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?				<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is the assembly installed on a non-potable water supply (auxiliary)?				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

	Reduced Pressure Principle Assembly (RPBA)			PVB & SVB	
	DCVA		Relief Valve	Air Inlet	Check Valve
	1 st Check	2 nd Check***			
Initial Test Date: 10/04/2024 Time: 3:20 pm	Held at 6.2 psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at 2.8 psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/> Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/>)	Held at _____ psid Leaked <input type="checkbox"/>
Test After Repair Date: Time:	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

*** 2nd check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: <input checked="" type="checkbox"/>	Non-Potable: <input type="checkbox"/>
Make/Model: Bac Flo 5	SN: 06163433	Date tested for accuracy: 10/11/2023

Remarks:

Company Name:	Safety Plus Services, LLC	Licensed Tester Name (Print/Type):	Scott Stevenson
Company Address:	102 Wonder World Dr #304-522 San Marcos, TX 78666	Licensed Tester Name (Signature):	<i>Scott Stevenson</i>
Company Phone #:	512-300-9659	BPAT License #	BP0017507
		License Expiration Date:	12/19/2025

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

TEST RESULT
PASS
FAIL