



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: **2460022**
 MAILING ADDRESS __ 114 Lansing Road Hutto, TX 78634 _____
 CONTACT PERSON __ Taylor Morrison _____
 LOCATION OF SERVICE 114 Lansing Road Hutto, TX 78634 _____
 INSPECTION DATE _10/30/2024_9:25AM _____

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- | | |
|--|--|
| <input type="checkbox"/> Reduced Pressure ZONE | <input type="checkbox"/> Reduced Pressure Principle-Detector |
| <input checked="" type="checkbox"/> Double Check Valve | <input type="checkbox"/> Double Check-Detector |
| <input type="checkbox"/> Pressure Vacuum Breaker | <input type="checkbox"/> Spill-Resistant Pressure Vacuum Breaker |

Manufacturer: Apollo _____
 Model # DC4A _____ Serial # 01348D _____
 Location of device Left front yard 5 feet from meter _____

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes _____

| | Reduced Pressure Principle Assembly | | | Pressure Vacuum Breaker | | |
|----------------------------|---|--|----------------------------------|-------------------------|--------------|-------------|
| | Double Check Valve Assembly | | Relief Valve | Air Inlet | | Check Valve |
| | 1st Check | 2nd Check | | Opened at psid | Held at psid | |
| Initial Test | Held at 1.9 Closed Tight X Leaked □ | Held at psid 2.2 Closed Tight X Leaked □ | Opened at psid Did not open □ | Did not Open □ | Leaked □ | |
| Repairs and Materials Used | | | | | | |
| Test After Repair | Held at psid Closed Tight □ | Held at psid Closed Tight □ | Opened at psid | Opened at psid | Held At psid | |

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 09231317 Calibration Date:3/14/2024

Firm Name Safewater Backflow Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765 Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS