

City of Georgetown - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping *purposes:

City of Georgetown
 PO Box 1430
 Georgetown, Texas 78626

PWS ID: 2460001
Contact Name: Water Regulatory
Phone Number: 512-930-3640

BPAT Information

Company Name: Safewater Backflow and Irrigation
Tester Name: Brad Weyant
Address: 609 E 50TH
 AUSTIN, Texas 78751

Phone Number: 5126059790
Email Address: brad@safewateratx.com
License Number: BP0016935
License Expiration: 12/3/2024

Location Information

Property Type: Residential
Business Name:
Property Address: 128 Poole Ln
 Georgetown, TX 78628

Contact Information

Company Name:
Contact Name:
Mailing Address: 128 Poole
 Georgetown, TX 78628
Phone Number:
Email Address:

Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

Backflow Method: Double Check Valve
Main Assembly Manufacturer: Apollo **Model:** DC4A **Size:** 1 **Serial Number:** 88850C
Location: Left front yard 5 feet from meter
Hazard Type **:** Irrigation - Non Chemical

Backflow Test Information

Test Result: Passed
Reason for Test: New Installation

Is the assembly installed in accordance with manufacturers recommendations and/or local codes? Yes

Is the assembly installed on a non-potable water supply (auxiliary)? No

Differential pressure gauge used: MidWest 845-5 (potable) **Serial Number:** 09231317 **Date Tested for Accuracy:** 3/14/2024

| | Double Check Valve | |
|---|--|--|
| | Check Valve #1 | Check Valve #2 |
| Initial Test Date: 8/7/2024 Time: 10:20 AM | Held at 2.1 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked | Held at 2.2 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked |
| Repairs and Materials Used | | |
| Repair Details | | |
| Test After Repairs | Held at 0 PSID <input type="checkbox"/> Closed Tight | Held at 0 PSID <input type="checkbox"/> Closed Tight |

Remarks

The above is certified to be true at the time of testing.
 * TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]
 ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS
 *** 2nd Check: Numeric reading required for double check valve only.
 **** Indicates additional information not present on the standard TCEQ report