

City of Georgetown - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping *purposes:

City of Georgetown
 PO Box 1430
 Georgetown, Texas 78626

PWS ID: 2460001
Contact Name: Water Regulatory
Phone Number: 512-930-3640

BPAT Information

Company Name: L Sinclair Services, Inc.
Tester Name: Lewis Sinclair
Address: 1307 Machado Road
 Cedar Park, Texas 78613

Phone Number: 512-563-8762
Email Address: lss@austin.rr.com
License Number: BP0002815
License Expiration: 2/12/2026

Location Information

Property Type: Residential
Business Name:
Property Address: 132 Rancho Deluxe
 Liberty Hill, TX 78642

Contact Information

Company Name:
Contact Name:
Mailing Address: 132 Rancho Deluxe
 Liberty Hill, TX 78642
Phone Number:
Email Address:

Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

Backflow Method: Reduced Pressure Principle
Main Assembly Manufacturer: Apollo **Model:** RP4A **Size:** 1 **Serial Number:** 48585C
Location: 12' WNW of water meter
Hazard Type **:** Irrigation - Non Chemical

Backflow Test Information

Test Result: Passed
Reason for Test: New Installation

Is the assembly installed in accordance with manufacturers recommendations and/or local codes? Yes

Is the assembly installed on a non-potable water supply (auxiliary)? No

Differential pressure gauge used: Mid-West 845-3 (potable) **Serial Number:** 10200408 **Date Tested for Accuracy:** 2/27/2024

Reduced Pressure Principle			
	Check Valve #1	Check Valve #2	Relief Valve
Initial Test Date: 10/10/2024 Time: 12:55 PM	Held at 7.5 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked	Held at __ PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked	Opened at 2.6 PSID <input type="checkbox"/> Did not open
Repairs and Materials Used			
Repair Details			
Test After Repairs	Held at 0 PSID <input type="checkbox"/> Closed Tight	Held at __ PSID <input type="checkbox"/> Closed Tight	Opened at 0 PSID

Remarks

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

*** 2nd Check: Numeric reading required for double check valve only.

**** Indicates additional information not present on the standard TCEQ report