

Texas Commission on Environmental Quality
BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	AQUA WATER SUPPLY CORPORATION
PWS ID#:	110013
MAILING ADDRESS:	415 Old Austin Hwy., Bastrop, TX 78602
CONTACT PERSON:	Chuck Kellogg
LOCATION OF SERVICE:	144 Weaver Lane, Bastrop, Texas 78602

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

- TYPE OF ASSEMBLY:** Reduced Pressure Principle Reduced Pressure Principle-Detector
 Double Check Valve Double Check-Detector
 Pressure Vacuum Breaker Spill-Resistant Pressure Vacuum Breaker

Manufacturer:	Apollo	Size:	1"
Model Number:	DC4A	Located At:	At meter - Front right
Serial Number:	64432C		

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes No

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1 st Check	2 nd Check			
Initial Test	Held at <u>2.4</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.0</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Opened at ___ psid Did not open <input type="checkbox"/>	Held at ___ psid Leaked <input type="checkbox"/>
Repairs and Materials Used**					
Test After Repair	Held at ___ psid Closed Tight <input type="checkbox"/>	Held at ___ psid Closed Tight <input type="checkbox"/>	Opened at ___ psid	Opened at ___ psid	Held at ___ psid

Test gauge used:

Make/Model:	Bac Flo 5	SN:	06163433	Date tested for accuracy:	10/11/2023
Remarks:					

The above is certified to be true at the time of testing.

Firm Name:	Safety Plus Services, LLC	Certified Tester Name (Print/Type):	Scott Stevenson
Firm Address:	102 Wonder World Drive #304-522 San Marcos, TX 78666	Certified Tester Name (Signature):	<i>Scott Stevenson</i>
Firm Phone #:	512-300-9659	Cert. Tester No.:	BP0017507
		Date of Test:	06/18/2024 1:20 pm

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

Type text here

AQUA WATER SUPPLY CORPORATION

P.O. Drawer P • 415 Old Austin Highway • Bastrop, Texas 78602
 (512) 303-3943 • PWS I.D. #: 0110013