

# City of Pflugerville - PWSID #2270014



## Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping \*purposes

### Customer Information

Customer / Property Name: **Resident**  
Contact Name: **N/A**  
Property Address: **15208 Bithal St  
Pflugerville, TX 78660**

### PWS Information

PWS Contact Name: **Aaron Griffith**  
PWS Phone Number: **(512) 990-6427**  
PWS Address: **15500 Sun Light Near Way #B  
Pflugerville, TX, 78691**

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

### Assembly Information

Type: **DC** Model #: **DC4A**  
Size: **1"** Serial#: **85619C**  
Manufacturer: **Apollo** BPA Serves: **Irrigation**  
Location: **Left front yard 5 feet from meter**  
Reason for test:  new  existing  replaced.  
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?  yes  no  
Water supply: Potable

# PASS

Test Date: 2024-06-14

## Assembly Test Information

Initial Test ( Time: 12:00 pm )	
Check Valve #1 : 2.0 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 2.1 (X) Closed Tight/Held ( ) Leaked
Final Test	
Check Valve #1 : 2.0 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 2.1 (X) Closed Tight/Held ( ) Leaked

As the tester of record, I affirm this test as: Passed  Failed  **Repairs Made:\*\* No**

Additional comments or repairs made / materials (parts) used:

**( no comments )**

### Tester Information

Tester Name: **Weyant, Brad**  
Tester License Expiration: **12-03-2024**  
Certification#: **BP0016935**  
Test Kit Serial #: **09231317**  
Test Kit Date Tested for Accuracy: **03-14-2024**  
Test Kit Mfr. & Mod. #: **Mid-West 845-5 (Potable)**  
Testing Co Name: **Safewater Backflow and Irrigation**  
Phone: **(512) 605-9790**  
Address: **PO Box 4002  
Austin, TX 78765**

The above tester certifies that all information submitted for this report is true and accurate

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters