Texas Commission on Environmental Quality BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	City of Leander			
PWS ID#:	2460012			
PWS MAILING ADDRESS:	PO Box 319 Leander, TX 78646			
PWS CONTACT PERSON:	Christi Williams			
ADDRESS OF SERVICE:	1565 Palo Verde Way, Leander, TX 78641			
The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations				

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):								
	Reduced Pressure Principle (RPBA)		Reduced Pressure Principle-Detector (RPBA-D)					
X	Double Check Valve (DCVA)		Double Check-Detector (DCVA-D)					
	Pressure Vacuum Breaker (PVB)		Spill-Resistant Pressure Vacuum Breaker (SVB)					

Manufacturer:	Apollo	Size:	1"
Model Number:	DC4A	BPA Location:	At meter - Front left
Serial Number:	53218C	BPA Serves:	Irrigation - City Potable

Reason for test: New	v 🔽 Existing	□ R	leplacer	nent 🛛 Old Mode	/Serial #			
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?								
Is the assembly installed on a non-potable water supply (auxiliary)?								
TEST RESULT	Reduced Pressure	Principle As	sembly	(RPBA)	PVB	PVB & SVB		
PASS 🗹	DCVA			Relief Valve	A in Inlat	Check Valve		
FAIL 🗆	1 st Check	2 nd Check*	***	Kellel valve	Air Inlet	Check valve		
Date 6/11/24	Held at <u>1.8</u> psid Closed Tight ☑ Leaked □	Held at <u>2.2</u> Closed Tigh Leaked		Opened at psid Did not open □	Opened at psid Did not open □ Did it fully open (Yes □ /No □)	Held at psid Leaked □		
Repairs and Materials Used**								
		Held at psid Closed Tight □		Opened at psid	Opened at psid	Held at psid		
***	^c 2 nd check: numeri	c reading rec	quired fo	or DCVA only				
Differential pressure gauge used:			Potable: 🗹 Non-I		Non-Potable:	-Potable:		
Make/Model: Bac Flo 5 SI			06163433Date tested for accur			: 10/11/2023		
Remarks: Leand	ler Todd Mud #1							
Company Name: Company Address:	Safety Plus Services, LLC 102 Wonder World Drive #304-522 San Marcos, TX 78666		Licensed Tester Name (Print/Type): Scott Stevenson Licensed Tester Name (Signature): Scott Stevenson					
Company Phone #:	512-300-9659				3P0017507			

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

**** USE ONLY MANUFACTURER'S REPLACEMENT PARTS**